



# Certificate / Certificat Zertifikat / 合格証

ABB 1704094 C001

exida hereby confirms that the:

**LLT100 Lidar Sensor**

**ABB**

**Quebec, QC - Canada**

The manufacturer  
may use the mark:



has been assessed per the relevant requirements of:

**IEC 61508 : 2010 Parts 1-3**

and meets requirements providing a level of integrity to:

**Systematic Capability: SC 2 (SIL 2 Capable)**

**Random Capability: Type B Element**

**SIL 2 @ HFT=0; Route 1<sub>H</sub>**

**PFH/PFD<sub>avg</sub> and Architecture Constraints  
must be verified for each application**

Revision 4.1 October 31 2023

Surveillance Audit Due  
December 31, 2024

### Safety Function:

The 4 to 20 mA current output will reflect the calibrated range in level, volume or ullage, as selected by the user, within the specified safety accuracy and safety time; and will change to 3.6 or 21 mA within the specified time upon detection of a failure.

### Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements. This includes detecting both 3.6 and 21 mA to indicate an LLT100 fault.



Evaluating Assessor

Certifying Assessor

ABB 1704094 C001

**Systematic Capability: SC 2 (SIL 2 Capable)****Random Capability: Type B Element****SIL 2 @ HFT=0; Route 1<sub>H</sub>****PFH/PFD<sub>avg</sub> and Architecture Constraints  
must be verified for each application**

Series LLT100

Lidar Sensors

**Systematic Capability:**

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 2. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

**Random Capability:**

The SIL limit imposed by the Architectural Constraints must be met for each element.

**IEC 61508 Failure Rates in FIT\*****FPGA version up to 1.1.3 | Software version up to 1.1.3**

Device	$\lambda_{SD}$	$\lambda_{SU}$	$\lambda_{DD}$	$\lambda_{DU}$
ABB LLT100	0	1559	2852	124

**Hardware version 2.0.0 | Software version 1.1.31**

Device	$\lambda_{SD}$	$\lambda_{SU}$	$\lambda_{DD}$	$\lambda_{DU}$
ABB LLT100	0	356	1659	118

\* FIT = 1 failure / 10<sup>9</sup> hours**SIL Verification:**

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD<sub>avg</sub> considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

**Assessment Report:** ABB 17-04-094 R001 V4R1

**Safety Manual:** AA019031-01 Rev C LLT100 SIL Functional Safety Guide



80 N Main St  
Sellersville, PA 18960