

产品认证证书

II型自愿认证

证书编号: CQC2013010304651497

发证日期: 2021 年 06 月 25 日

有效期至: 2023 年 09 月 05 日

委托人名称	ABB France
及注册地址	2 rue d'Arsonval 69680 Chassieu France
制造商名称	ABB France
及注册地址	2 rue d'Arsonval 69680 Chassieu France
生产企业名称	Deltaplast Poland
及生产地址	Armii Krajowej 8,05-500 Piaesczno POLAND
产品名称和系列、 规格、型号	辅助触点 CA4-***,CAT4-***,VE4;Ui:690V; Uimp:6kV; Ith:16A ; AC-15:Ue/Ie:24-127V/6A,220-240V/4A,380-440V/3A,500-690V/2A; DC-13:Ue/Ie:24V/6A,48V/4A,72V/1A,110-125V/0.55A,220-250V/0.27A,400V/0.15A, 500V/0.13A,600V/0.1A ; 外壳防护等级: IP20;型号解释详见附件;
产品标准和技术要求	GB/T 14048.5-2017
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020 年 08 月 21 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

陈昕

陆楠



中国质量认证中心

产品认证证书

II型自愿认证

证书编号: CQC2013010304651497

第 1 页 共 3 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号:

型号解释:

NOMENCLATURE:

CA4 40 E **

I II III IV

I - Main designation

CA4 Auxiliary contacts module, front mounted

II - Auxiliary Pole Construction

04 - 4 normally closed auxiliary pole provided.

11 - 1 normally opened and 1 normally closed auxiliary poles.

13 - 1 normally opened and 3 normally closed auxiliary poles.

22 - 2 normally opened and 2 normally closed auxiliary poles.

31 - 3 normally opened and 1 normally closed auxiliary poles.

40 - 4 normally opened auxiliary pole provided.

III - Contact arrangement

E or M or N or U or SP

IV - Connection type

Blank = Screw type connection

K = Push-In connection

S = Spring type connection

RT = Ring Tongue connection

NOMENCLATURE:



中国质量认证中心

产品认证证书

II型自愿认证

证书编号: CQC2013010304651497

第 2 页 共 3 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号:

CAT4 11 E **

I II III IV

I - Main designation

CAT4 Auxiliary contacts module, front mounted

II - Auxiliary Pole Construction

11 - 1 normally opened and 1 normally closed auxiliary poles.

III - Contact arrangement

E or M or U

IV - Connection type

Blank = Screw type connection

S = Spring type connection

RT = Ring Tongue connection

VE4 - Electrical interlock

List of type

Designation
CA4-04E or M or N or U
CA4-04MK or NK
CA4-11ERT or MRT



中国质量认证中心

产品认证证书

II型自愿认证

证书编号: CQC2013010304651497

第 3 页 共 3 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号:

CA4-13M or N or SP
CA4-13MK or NK
CA4-22E or M or N or U
CA4-22ES or MS or NS
CA4-22EK or MK or NK
CA4-22ERT or MRT or NRT or URT
CA4-31E or M or N or U
CA4-31ES or MS or NS
CA4-31EK or MK or NK
CA4-31ERT or MRT or NRT or URT
CA4-40 E or N or U
CA4-40ES or NS
CA4-40EK or NK
CA4-40ERT or NRT or URT
CAT4-11E or M or U
CAT4-11ES or MS or US
CAT4-11ERT or MRT
VE4



中国质量认证中心