

CERTIFICATE

No: VNO 10190001

Product: RIP Bushing

Type/Model: BRIT-S-90-220-1050/2000

Applicant: **ABB Ltd.**
Nakhimovskiy prospect 58
Moscow, Russia

Manufacturer: **ABB Ltd.**
Nakhimovskiy prospect 58
Moscow, Russia

Related standards: **IEC 60137:2017**

Test report No. and date of issue: Test Report No. 058318 dated 14.01.2019

Test report issued by: **KONČAR-Electrical Engineering Institute, High Voltage Laboratory**
Fallerovo šetalište 22,
HR-10002 Zagreb, Croatia

CONCLUSION:

The sample of the product is in accordance with requirements of the standards listed above.

REMARK:

This document is a certificate of conformity of the tested sample. The applicant is responsible for conformity of product with the same type/model name.

Period of validity:

21.01.2022.

Place and date:

Croatia, Zagreb, 22.01.2019.

**KONČAR - Institut za
elektrotehniku d. d.
ZAGREB 12**

Assessor

Dalibor Filipović-Grčić, Ph.D.E.E.



Seal

Head of Certification Department

Sanda Kozlik, Mechanical Engineer, MBA

