

Certificate of Conformity

No. ESY 044254 0042 Rev. 00

Holder of Certificate: **ABB Stotz-Kontakt GmbH**
Eppelheimer Str. 82
69123 Heidelberg
GERMANY

Product: **Protection System**

Model(s): CM-UFD.M22M
CM-UFD.M22

Parameters: see next pages

Applicable standards: CEI 0-21:2022

This Certificate of Conformity confirms the compliance with the above listed standards on a voluntary basis. It refers only to the sample submitted to TÜV SÜD Product Service GmbH and does not certify the quality or safety of the serial products. It was issued according to TÜV SÜD Product Service certification program Photovoltaics and Grid Integration. For details see: www.tuvsud.com/ps-cert

Test report no.: 713263571-000

Date, 2022-07-22



(Kristijan Cizmar)

Certificate of Conformity

No. ESY 044254 0042 Rev. 00

CEI 0-21:2022 – Reference technical rules for the connection of active and passive users to the LV electrical utilities	
Test report of the CEI 0-21:2022 specifications for SPI	No. 713263571-000

Applicant	ABB Stotz-Kontakt GmbH Eppelheimer Str. 82, 69123 Heidelberg, Germany
Manufacturer	ABB Stotz-Kontakt GmbH Eppelheimer Str. 82, 69123 Heidelberg, Germany

Product type:	Interface Protective Device	Static Conversion Device
	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Model reference:	Models	Specifications
	CM-UFD.M22M CM-UFD.M22	Power supply: 24-240Vac / 24-240Vdc Monitoring line: 230/400 50Hz

Firmware:	rev. 1.0.x
Phase numbers:	3-phase / single phase (optinal)
Tested at:	TÜV SÜD Product Service GmbH Äußere Frühlingstraße 45, 94315 Straubing, Germany
Measurement period:	From 2017-03 to 2017-05