



| Test Report | | | | Date of issue: 4.6.2014 | | | | | |
|--|---------------------------------|--------------|------------------|--|----------------------------------|--|--------------------|-------|-------|
| | | | | Serial No.: 3GF11094432 | | | | | |
| | | | | Type: M3KP 200MLB 8 IMB3/IM1001 | | | | | |
| | | | | Product Code: 3GKP204420-ADG | | | | | |
| | | | | Protection type: Ex de IIB T4 Gb | | | | | |
| | | | | Cert. No.: LCIE 10 ATEX 3061X / IECEx LCI 04.0011X | | | | | |
| Rating: | | | | | | | | | |
| | V | Hz | kW | r/min | A | cos φ | Duty | | |
| 3~Motor | 690 | Y 50 | 18,5 | 734 | 21,5 | 0,80 | S1 | | |
| Insul.cl.F | 400 | D 50 | 18,5 | 734 | 37,1 | 0,80 | S1 | | |
| IP55 | 415 | D 50 | 18,5 | 735 | 36,7 | 0,78 | S1 | | |
| Resistance | | | Ambient: 17,5 °C | | Insulation resistance at 34,5 °C | | Overload | | |
| Line | U ₁ - V ₁ | | 0,40740 Ω | | 8000 MΩ 1000 V | | Torque 160 % 15s | | |
| | U ₁ - W ₁ | | 0,40780 Ω | | | | | | |
| | V ₁ - W ₁ | | 0,40770 Ω | | | | | | |
| | | | | High-voltage test winding 2900 V | | 1 s | | | |
| Test | Torque [Nm] | Line U[V] | f[Hz] | Input I[A] | P1 [kW] | Output P2 [kW] | n[r/min] | cos φ | η [%] |
| No load test | | 400,1 D | 50 | 16,4 | 0,68 | | 750 | 0,06 | |
| Locked rotor test | | 91,2 D | 50 | 37,1 | 2,20 | | 0 | 0,38 | |
| Thermal test (100% load) | 240,7 | 400,1 D | 50 | 37,1 | 20,8 | 18,5 | 733 | 0,81 | 88,8 |
| Partial load points: | | | | | | | | | |
| ~75% load | 180,3 | 400,0 D | 50 | 29,6 | 15,5 | 13,9 | 738 | 0,76 | 89,4 |
| ~50% load | 120,2 | 400,1 D | 50 | 23,1 | 10,5 | 9,25 | 743 | 0,65 | 88,4 |
| ~25% load | 60,1 | 400,0 D | 50 | 18,3 | 5,59 | 4,62 | 746 | 0,44 | 82,7 |
| Temperature rise at rated load. | | | °C | K | Method | | Measurement method | | |
| Stator winding : | | | 58,7 | 1 | 1 | | Resistance | | |
| Frame : | | | 36,7 | 2 | 2 | | Thermometer | | |
| Bearing D-end : | | | 46,5 | 2 | 2 | | Thermocouples | | |
| Ambient Temperature : | | | 25,0 | 2 | | | | | |
| Manufactured and tested in accordance with rules of IEC 60034-1 and IEC 60034-2-1. PLL determined from residual loss. | | | | | | | | | |
| On behalf of customer | | | | | | | | | |
| On behalf of manufacturer | | Date of test | | 4.2.2012 | | | | | |
| Tested by ABB Oy, Motors and Generators, Vaasa, Finland | | | | | | Telephone +358 10 2211 Telefax +358 10 22 47372 | | | |

Computer print-out valid without signature.