

CYBERSECURITY ADVISORY

# **BadAlloc – Memory Allocation Vulnerabilities in Hitachi ABB Power Grids Modular Switchgear Monitoring System (MSM) Product**

**CVE-2020-28895**  
**CVE-2020-35198**

## **Notice**

The information in this document is subject to change without notice and should not be construed as a commitment by Hitachi ABB Power Grids. Hitachi ABB Power Grids provides no warranty, express or implied, including warranties of merchantability and fitness for a particular purpose, for the information contained in this document, and assumes no responsibility for any errors that may appear in this document. In no event shall Hitachi ABB Power Grids or any of its suppliers be liable for direct, indirect, special, incidental or consequential damages of any nature or kind arising from the use of this document, or from the use of any hardware or software described in this document, even if Hitachi ABB Power Grids or its suppliers have been advised of the possibility of such damages. This document and parts hereof must not be reproduced or copied without written permission from Hitachi ABB Power Grids and the contents hereof must not be imparted to a third party nor used for any unauthorized purpose. All rights to registrations and trademarks reside with their respective owners.

## Affected Products and Versions

List of affected products and product versions:

Modular Switchgear Monitoring System MSM – version 2.2 or prior (running VxWorks v6.9)

## Vulnerability ID

- CVE-2020-28895
- CVE-2020-35198

## Summary

Hitachi ABB Power Grids is aware of a two critical memory allocation vulnerabilities (called BadAlloc [1] vulnerabilities) in the WindRiver VxWorks Operating Systems [2][3] that are used in our product versions listed above.

An attacker that exploits these vulnerabilities might bypass security controls to execute malicious code or cause a system crash.

For immediate mitigation/workaround information, please refer to the Mitigation Factors/Workaround Section below.

## Vulnerability Severity and Details

The severity assessment has been performed by using the FIRST Common Vulnerability Scoring System (CVSS) v3.1. The CVSS Environmental Score, which can affect the vulnerability severity, is not provided in this advisory since it reflects the potential impact of a vulnerability within the end-user organizations' computing environment; end-user organizations are therefore recommended to analyze their situation and specify the Environmental Score.

| CVE ID   | Detail Description   |
|--|--|
| <b>CVE-2020-28895</b><br>CVSS v3.1 Base Score: 7.3 High<br>CVSS v3.1 Vector: /AV:N/AC:L/PR:N/UI:N/S:U/C:L/I:L/A:L<br>Link to NVD: click <a href="#">here</a>     | In Wind River VxWorks, memory allocator has a possible overflow in calculating the memory block's size to be allocated by <code>calloc()</code> . As a result, the actual memory allocated is smaller than the buffer size specified by the arguments, leading to memory corruption.                                     |
| <b>CVE-2020-35198</b><br>CVSS v3.1 Base Score: 9.8 Critical<br>CVSS v3.1 Vector: /AV:N/AC:L/PR:N/UI:N/S:U/C:H/I:H/A:H<br>Link to NVD: click <a href="#">here</a> | An issue was discovered in Wind River VxWorks 7. The memory allocator has a possible integer overflow in calculating a memory block's size to be allocated by <code>calloc()</code> . As a result, the actual memory allocated is smaller than the buffer size specified by the arguments, leading to memory corruption. |

## Recommended Immediate Actions

The Table below shows the affected version and the recommended immediate actions.

| Affected Version                                  | Recommended Actions  |
|---|--|
| MSM – version 2.2 or prior (running VxWorks v6.9) | Refer to recommendation in Mitigation Factors/Workaround Section |

## Mitigation Factors/Workaround

Recommended security best practices and firewall configurations can help protect a process control network from attacks that originate from outside the network. Such practices include ensuring critical applications and systems are physically protected from direct access by unauthorized personnel, have no direct connections to the Internet, and are separated from other networks by means of a firewall. Firewalls should be configured to have the minimum number of ports exposed and open ports should be justified and documented. Critical systems should not be used for Internet surfing, instant messaging, or receiving e-mails. Portable computers and removable storage media should be carefully scanned for viruses before they are connected to a control system. It is important to implement robust security awareness training to ensure users are able to identify common attacks or content such as phishing E-Mails or malicious web pages.

Additionally, please refer to the mitigation strategy that is proposed by Microsoft Section 52 team [1] who discovered these vulnerabilities.

## Frequently Asked Questions

### What is the scope of the vulnerability?

An attacker who successfully exploited this vulnerability might bypass security controls in the device in order to execute malicious code or cause a system crash.

### What causes the vulnerability?

The vulnerability is caused by memory allocation errors.

### What is the affected product?

The Hitachi ABB Power Grids Modular Switchgear Monitoring System is a product to monitor i.e., analyze condition of high-voltage switchgear like dead tank breakers (DTB), live tank breakers (LTB), gas-insulated switchgear (GIS) and Plug and Switch System (PASS) hybrid switchgear. Please refer [Modular Switchgear Monitoring \(MSM\) \(hitachiabb-powergrids.com\)](https://www.hitachiabb-powergrids.com) for more information about this product.

### What might an attacker use the vulnerabilities to do?

An attacker who successfully exploited this vulnerability could crash the device repeatedly to cause a denial-of-service and may be able to also execute malicious code on the device leading to incorrect monitoring operation by the device.

### How could an attacker exploit these vulnerabilities?

There is no known exploitation of these vulnerabilities in general and also for MSM.

### Could the vulnerabilities be exploited remotely?

Yes, the vulnerability can potentially be exploited by anyone with network access to the application interface.

### When this security advisory was issued, had this vulnerability been publicly disclosed?

Yes, Hitachi ABB Power Grids received information through a public disclosure that is released by Microsoft's Section 52 Team [1].

## When this security advisory was issued, had Hitachi ABB Power Grids received any report that this vulnerability was being exploited?

No, Hitachi ABB Power Grids had not received any information indicating that this vulnerability had been exploited when this security advisory was originally issued.

## References

1. BadAlloc – Microsoft’s Section 52 - <https://msrc-blog.microsoft.com/2021/04/29/badalloc-memory-allocation-vulnerabilities-could-affect-wide-range-of-iot-and-ot-devices-in-industrial-medical-and-enterprise-networks/>
2. Wind River VxWorks – CVE-2020-28895 Advisory - <https://support2.windriver.com/index.php?page=cve&on=view&id=CVE-2020-28895>
3. Wind River VxWorks – CVE-2020-35198 Advisory - <https://support2.windriver.com/index.php?page=cve&on=view&id=CVE-2020-35198>

## Support

For additional information and support please contact your product provider or Hitachi ABB Power Grids service organization. For contact information, see <https://www.hitachiabb-powergrids.com/contact-us/> for Hitachi ABB Power Grids contact-centers.

## Revision

| Date of the Revision | Revision | Description  |
|----------------------|----------|--|
| 2021-08-19           | A        | Initial public release.  |
| 2021-09-07           | B        | Update: <ul style="list-style-type: none"><li>• the Summary section – 2nd paragraph;</li><li>• answer to FAQ 1<sup>st</sup> question</li></ul> |