


Type Circuits & Functions
Short Introduction



1. INTRODUCTION	3
1.1. General	3
1.2. More Information	3
2. NETWORK CONFIGURATION DETERMINATION	4
3. LOAD SHEDDING	4
3.1. General	4
3.2. Primary Load Shedding	5
3.3. Frequency Load Shedding.....	5
3.4. Manual Load Shedding.....	6
3.5. Maximum Peak Power Demand Shedding.....	6
4. RE-ACCELERATION	6
5. POWER CONTROL	6
5.1. Active Power Control	6
5.2. Re-active Power Control.....	7
5.3. Auto Sequencer.....	8
5.4. Default Island Mode Settings.....	8
6. GENERATOR CONTROL	9
7. SYNCHRONISATION.....	9
8. BREAKER CONTROL.....	10
9. MOTOR CONTROL	10
10. TAP CHANGER CONTROL.....	10
10.1. Operating Principles	11
10.2. On-Load Parallel Control	11

1. INTRODUCTION

1.1. General

This document, "*ABB Advant Energy Management Functions & Type Circuits Short Introduction*" for Master software, contains a brief description of all functions of the ABB Advant Energy Management Systems.

Advant EMS provides economical control and supervision of the power -generation and -supply in industrial plants. The main reason for considering the Advant EMS is very often the need for Load Shedding. This system drastically increases the overall plant safety by assuring electrical power and steam for critical loads and avoids blackouts. The costs, caused by production losses, of a complete blackout easily can go up to one million USD per blackout. With the provided tools it is possible to ensure safe operations with less personnel. Better, faster and more comprehensive information from the process is thus a necessity. For many (petro-)chemical, steel and cement industries the costs for energy form at least 30 -50 % of the production costs. The Advant EMS increases the efficiency and the pay back time of the system is very short (<less than 2 years).

Advant EMS allows for more critical designs of the electrical equipment in a plant. The Advant EMS will re-arrange generation, importation and loading in such a way that the individual generators, reactors, transformers, and tie-lines are operated well within their specifications. The integration and serial communication with Motor Control Centres, Protection Units, Governor controllers, Variable Speed Drives and other subsystems give high savings in copper wiring and maintenance cost s. The optical connections provide a rigid network that does not suffer from electromagnetic interference.

Since 1986 ABB Systemen BV in Rotterdam, the Netherlands has been actively working in the field of Industrial Electrical Energy Management Systems (Advant EMS). Realising projects all around the world, the power automation group has built up specific application know how regarding the control and monitoring of electricity networks for industrial process plants. The Advant EMS functionality has gained wide acceptance among its users.

Since January 1996 ABB Systemen BV is the product responsible unit (PRU) for the applications for this type of energy management systems within the business unit COG of ABB Automation. A wide range of products is available to allow for a cost-efficient and reliable engineering of the EMS systems. The well -tested and documented products (software type circuits and system software modules) guarantee a significantly decreased project execution time and (even more important) shorter commissioning periods.

In case, projects are run by the local ABB Automation companies or Regional Centres, ABB Automation Benelux can support these projects either by supporting man-hours or by providing tools like project quality control plans, frames for functional design specifications and pre -defined project time schedules. These tools help in order to achieve a smooth and optimised project execution.

1.2. More Information

For a more complete exposition of ABB Advant Energy Management Systems, please contact:

ABB Systemen BV
Department NLSYS/YAV-I
PO Box 2714
3000 CS Rotterdam
The Netherlands

Otto van der Wal
Phone: +31 10 4078 622
Telefax: +31 10 4078 433
E-mail: otto.wal@nl.abb.com

2. NETWORK CONFIGURATION DETERMINATION

The "Network Configuration Determination" function analyses the electrical network configuration determined by the status of the tie-line breakers, buscouplers and generator breakers. The results of this function are used by other functions, such as the later described functions auto sequencer, load shedding, re-acceleration, active power control, reactive power control, transformer control and generator control.

The electrical network has a number of breakers of which the status determine the actual network configuration(s). When the status of the breakers (connect/disconnect busbars) are read, the function generates the actual network configuration. The results are written in a register. The outputs of the register are used by the other functions. In the electrical network, many possible network configurations can be determined. A network configuration is defined by the checked and approved, opened or closed position of the breakers involved. The status of these breakers are input for the network determination.

Each breaker can have two positions, either opened or closed. If one of these breakers has an intermediate position, then this is a non-existing configuration and an audible alarm is created. It is assumed that the network configuration change is not succeeded. An electrical island is only of interest if it consists of at least one machine. If, for example, a maximum of 6 machines are in operation, no more than 6 islands can be formed simultaneously.

3. LOAD SHEDDING

3.1. General

The load shedding system has to ensure the availability of electrical power to all essential and most critical loads in the plant. This is achieved by switching off non essential loads in case of a lack of power in the plant electrical network, or parts of the plant electrical network. A lack of electrical power can be caused by loss of generation capacity or disconnection from the public power company supply.

The load shedding system can be implemented by one or more of the following functions:

- primary load shedding
- frequency load shedding
- manual load shedding
- maximum peak power demand shedding

Main input to the load shedding system is the register received from another function of the ABB Advant EMS function called "Network Configuration Determination", which determines the configuration of the electrical network. The configuration is determined from the checked breaker positions.

Secondly, load shedding needs data from the loadflow in the network. Data regarding the loads on the busses and the power generated by each generator is sent to the central load shedding function by analogue inputs and software has already checked the validity of the data. Where available, the measured power of each load is used. This data can be received from the analogue inputs in the process controllers or via serial links to the MCC's. When there is no power measurement available for a particular load, the belonging position of the breaker is used together with the nominal power value. Load shedding uses data representing the loadflow in the network, which is at least 2 seconds old, to prevent load shedding from using data which was obtained while the network was already in a faulty and thus unstable condition.

The third group of data needed by load shedding is the operator input. For the load shedding functionality maximum 20 priorities are used. For each load all priorities can be defined by the operator. Priority 20 is reserved for all non-sheddable loads or loads which are disabled for load shedding. Within each priority also 10 groups can be assigned. A group is the smallest sheddable unit. For each load with the load shedding option, the operator from central point of control is able to change the priority and enable/disable the load shedding function.

The operating time from opening a circuit and read in by a digital input in any of the Advant Controllers to giving the load shed command, at a particular output in any of the Advant Controllers, is maximum 150 milliseconds. For the crisis signals, the transducer reading is not used when determining whether a breaker is open. This is because of the fact the transducer takes approximately 300 milliseconds to settle, this time would make the load shedding action too slow. Preferred, if possible, a 2 out of 3 reading is to be used for the circuit breaker positions, which are used as crisis signals.

3.2. Primary Load Shedding

The following main functions are included in the primary load shedding system:

- continuously checking changes into the total electrical network configuration
- continuously checking the energy balance in every electrical island configuration
- calculation of the dynamic priority load tables
- generation of the load shed command when needed
- supervision of the total ABB Advant EMS computer system
- generation of reports after load shedding
- informing and guiding of the operators

The load shedding system continuously checks whether changes in the island configuration have occurred. As soon as a change occurs, for example tripping of a generator, the load shedding system starts checking all the individual island configurations. For every island configuration, the energy balance has to be calculated. If the load in this island configuration exceeds the available generated power, it is necessary to shed the surplus of loads.

For every island configuration, which is momentarily in a steady state condition, the load shedding system has to monitor continuously the power available from the generators in that particular island configuration, since losing a generator or losing part of the capacity of a generator might cause the need for load shedding.

As soon as load shedding is started due to a change in the electrical network configuration, not meaning that a real shed command is generated, the system starts calculating the dynamic priority load shed tables. Input for this calculation is the data in the island configuration and the priority load tables for the several busses. For every bus on which there are sheddable loads, such a priority load table is assembled.

The priority load table for every bus is assembled in order of priority. Calculation of the priority load table is done in the background. From this priority load table an accumulated priority load table per bus is obtained. As soon as load shedding is started, an accumulated priority load table for the whole island configuration is calculated. If the result of the energy balance calculation leads to the conclusion that load shedding is needed, the amount of power to be shed is also obtained from this energy balance calculation. This amount is now compared with the contents of the accumulated priority load table for the island configuration. The load shed command is generated and sent fast to the unit where the loads are actually connected. The primary load shedding functionality is implemented into two parts:

- central part
- substation part

The central part of primary load shedding functionality is implemented in the central node. The substation part of primary load shedding functionality is implemented in the one or more substation nodes. For small load shedding applications, the central- and the substation part of the primary load shedding can be implemented into central node.

3.3. Frequency Load Shedding

This function is more or less the backup for the primary load shedding function, which is described in chapter 3.2. When the primary load shedding fails due to wrong inputs, this function will shed the loads. Frequency load shedding not only takes the absolute frequency limits into account, but also calculates the df/dt . This gives a more accurate load shedding. The frequency limits are read in from frequency relays by digital inputs in the Advant Controller.

3.4. Manual Load Shedding

The operator can issue a plant-wide shed priority. To assist the operator in assessing how much load will be shed if the operator issues a manual load shedding priority, in the main load shedding process display an accumulated priority load table for the total actual plant load per priority is presented.

3.5. Maximum Peak Power Demand Shedding

Some priorities are shed as soon as the power taken from the public grid is tending to supersede the maximum allowed amount when the in-house generation is maximised. This import maximum is based on periodically power demand. In this case, the operator can deactivate the mechanism, and also determine up and until which priorities may be shed automatically by this function. Certain priorities can be inhibited from maximum peak power shed. Before the shed command, an audible alarm is created. So an action can be taken, if there is time, to overcome the situation.

4. RE-ACCELERATION

In case of faulty situations, such as bus under-voltage or load shedding, the loads are disconnected from the bus. The purpose of the function re-acceleration is to determine which loads can be reconnected as soon as the network or parts of the network recovered from the under-voltage situation or the operator released the function re-acceleration after load shedding by giving a general reset.

Re-acceleration is executed in priorities and maximum disconnected times, defined in tables. The system determines which loads can be re-accelerated taking into account:

- available island power
- priorities
- restart time
- network stability timer

Any load shedding action, either primary or thermal load shedding or manual shedding, stops the execution of re-acceleration.

To execute the re-acceleration function as efficient as possible, the distribution of available power is executed in several 'power assignment' steps, thus making re-acceleration an iterative process.

While the start-up load of most electric loads is much larger than the load in normal operation, it is possible that with the power that is assigned to the substation, only a few loads can be re-accelerated. After these few loads have been started up, the power consumption decreases to a fraction of the available power.

There will still be power available to start-up other loads. All substation nodes again access the amount of power that can be re-accelerated.

If from all substations the 'ready' signals are received, a next power distribution calculation is executed. Re-acceleration stops if all delay timers of the loads have expired, as indicated in the substation nodes. If re-acceleration load from the substations equals zero and all ready bits are received, re-acceleration is finished. If loads have been shut-off by load shedding, re-acceleration starts if a reset load shedding signal has been issued by the operator.

5. POWER CONTROL

5.1. Active Power Control

The "Active Power Control" covers the system wide functions:

- **MW demand control**

To ensure that the amount of imported power is kept at the desired setpoint, if possible with the available in-plant generation. The function also has to take care that contracted peak demand, in most cases measured as a sliding 15 minutes demand, is not exceeded.

- **Bus frequency control**

The bus frequency control function has the objective to maintain/re-establish the bus frequency at the desired frequency for a certain busbar or a combination of busbars in case the busbar or island is disconnected from the public grid. The latter especially in case the electrical load of the busbar is changing.

For every island only one machine can be the “master of frequency”. Frequency control could be done either be a separate controller which is enabled by the bus frequency function and receives it’s setpoint from this module, or directly by the generator control type circuit in the ABB Advant EMS and the machine running in droop mode. In the latter case the frequency is maintained sending raise/lower pulses to the governor. Enabling frequency control for a machine is interlocked as long as the machine is connected to the public grid or to another machine which is the master of frequency. As soon as the frequency exceeds a high or a low limit an audible alarm is created.

- **MW sharing control**

If two or more machines are operating in parallel in the same electrical network and this network is not connected to the public grid, one of the machines very often is operating in frequency or isochronous mode. The result of this is that the machine in frequency mode takes all the load changes in this particular island, while the other machines, which might run in MW mode, keep operating in the same working point. This could result in a situation where one machine is running very close to the limits of it’s capability curve while the other machines are running quite comfortably well within the limits of their capability curve. This should be avoided.

The MW sharing function re-calculates the working point of the machines connected in the concerned electrical network and for which MW sharing control is enabled. The re-calculation again is done by comparing the actual working point to the borders of the capability curve (control margin).

In these controls at least one machine is participating, but usually more than one machine is involved. For each machine an individual generator control type circuit is implemented, as described into chapter 6.

The active power control sends setpoints to each generator control module which is enabled to take part in that particular control action.

Whether it is possible to enable one of the above control modes, depends on the electrical network configuration which is determined by the “Network Configuration Determination” function.

5.2. Re-active Power Control

The ABB Advant EMS has facilities to control the setpoint given to the controllers (AVR’s) of the power generation units. The setpoints are given only if the system or the operator sets the AVR’s control module of the involved power generation units in PF control mode.

The “Reactive Power Control” function optimises the amount of reactive power exchanged with the PPC or follows a setpoint for the power factor. It does this by optimising the reactive power generated by the power generation unit. The reactive power to be generated by these units is divided over the units according their possibility of taking more reactive load. In case the electrical plant network is in island operation the reactive power control function controls the voltage and gives the setpoint to the AVR.

The reactive power control function has the ability to calculate the capability curve of the units. From this capability curve the module determines how to divide the reactive power. This function covers the system wide functions:

- **PF demand control or MVAr control**

The PF demand control function offers the possibility to maintain an adjustable power factor setpoint at the exchange point with the public grid. The setpoint is usually determined by the contracted minimum power factor.

Depending on the contract with the public power company the algorithm is tuned. Often the decisive moment for the power factor is related to the maximum peak power demand in active power. Apart from the criteria given by the contract the operator has the opportunity to give a setpoint into the system. This allows to operate on the safe side.

- **Voltage control**
*The voltage control function has the objective to maintain the busvoltage at a desired level, even after major load changes. In any electrical island only one generator can be set to control the voltage. Which generator is controlling the voltage in an electrical island is determined by the "Network Configuration Determination" function in conjunction with a pre-prepared table.
In electrical islands that are connected to the public grid the transformer voltage control takes care of the busvoltages.*
- **MVAr sharing control**
*If two or more machines are operating in parallel in the same electrical network, and this network is not connected to the public grid, one of the machines very often operates in voltage mode. The result of this is that the machine in voltage mode takes all the reactive load changes in this particular island, while the other machines which might run in MVAr control mode keep operating in their same working point. This could result in a situation where one machine is running very close to the limits of its capability curve while the other machines are running quite comfortably well within the limits of their capability curve. This should be avoided.
The MVAr sharing control function re-calculates the working point of the machines connected in the concerned electrical network and for which the MVAr sharing control mode is enabled. The re-calculation is again done by comparing the actual working point to the borders of the capability curve (control margin).
MVAr sharing control mode can only be enabled for the machines that are islandized from the grid. Audible alarms are created as soon as machines in MVAr sharing control mode are operated too close to their respective capability curve.*

In these controls at least one machine is participating, but usually more than one machine is involved. For each machine an individual generator control type circuit is implemented, as described in chapter "Generator Control".

The reactive power control module sends setpoints to each generator control that is taking part in that particular control action.

Whether it is possible to enable one of the above control modes, depends on the electrical network configuration which is determined by the "Network Configuration Determination".

5.3. Auto Sequencer

As the governor- and AVR control mode of a machine are subject to the network configuration the machine participates in, network configuration changes might need to change actual control modes. The "Auto Sequencer" function sends after a network configuration change, a message to all participating objects with the desired operating mode. These operating modes are stored in the table called "Default Island Mode Settings" (DIMS). This table can be defined by the operator and has only a meaning for island configurations.

To be able to do so, the "Auto Sequencer" function continuously receives the actual electrical network configuration from the "Network Configuration Determination" function. The operator is always allowed to change the actual mode of an individual machine.

If the "Auto Sequencer" function changes a control mode of the governor or the AVR of one of the machines, an audible alarm is created.

5.4. Default Island Mode Settings

To allow for easy mode changes, there are no interlocks between modes or mode changes in the DIMS table. However, for each island configuration an indication is created to warn the operator in case a setting in the DIMS results in an erroneous operation mode of the machines. The conditions for messages are restricted for the status of objects in one power station only.

There are no interlocks between the DIMS table set-up and the actual control mode of the machine dialogue. After the set-up in the DIMS table has changed, the operator has to verify that no warning exists. As long as a warning for a configuration exists, the set-up for that configuration is not valid.

If the operator ignores the warning, the “Auto Sequencer” function will change the governor and/or AVR to the droop control mode if the warning is active at the very moment that configuration is detected.

A change according to the DIMS table set-up can be made at once for all machines of one powerhouse from a special DIMS table dialogue, or manually by selecting the individual machine concerned.

6. GENERATOR CONTROL

For each machine in the electrical network, the “Generator Control” function is used. The “Generator Control” function is able to operate machines in different electrical network configurations, in island and in parallel. The “Generator Control” function is also able to co-operate with the “Active Power Control” and “Reactive Power Control” functions.

For each machine a control mode can be selected for both governor and automatic voltage regulation (AVR) individually. The behaviour of the machine is subject to this control mode and to changes or fluctuations detected in the electrical network or steam system. Some control modes can be selected only in dedicated network configurations.

In the single line diagram displays of the electrical network, the generators are only presented by the most important actual measured analogue data. Dedicated displays are available for more detailed generator information, e.g.:

- **Generator Overview**
Detailed generator data is presented in a table regarding the actual control mode of the governor and the AVR, working setpoint and some alarms.
- **Capability Diagram**
The capability diagram of the generator includes dynamic working point tracking, actual control mode, setpoint, working point and all related analogue data.

7. SYNCHRONISATION

The synchronisation function implemented into the “Generator Control” function is started by selection of the generator breaker from central point of control. When synchronisation is required, the generator name to use for the synchronisation can be entered by the operator, where after the generator dialogue automatically will be presented and will be set into droop control mode. By selection of the synchronisation command from the generator dialogue, the synchronisation can be continued into manual or automatic mode.

The ABB Advant EMS system offers the operators the capability to synchronise automatically. The selection of the circuitbreaker and the belonging generator is done from the ABB Advant Operator Station. The software module determines which voltages should be applied to the synchroniser, relays are activated by the control system in such a manner that these voltages are actually applied to the synchroniser. The synchroniser will send the pulses raise/lower to the appropriate governor and the exciter again by means of a relay circuitry that is controlled by the control system. At the moment synchronism is reached the synchroniser will release the close command. We assume that there is a synchrocheck relay available for each circuitbreaker to be synchronised.

The synchronisation module also allows for manual and semi-automatic synchronisation. In manual mode the operator has to give raise/lower commands from the keyboard and as soon as synchronism is reached give the close command. The close command has to be released by a synchrocheck function obviously. This synchrocheck function can be locally at the circuitbreaker or be included in the synchroniser which is located in the central system.

In semi-automatic mode the raise/lower commands are given by the synchroniser but the actual closing command is still given by the operator. Again this command has to be validated by a synchrocheck functionality.

8. BREAKER CONTROL

The breaker control can be used for one or more point of control (remote, central and/or local). The breaker control is accomplished with a basic section (status conditioning and supervision, command supervision, support of different position limit switches) and a number of optional additional functions.

The breaker control is accomplished for a single (synchronising) breaker or disconnecter and for control of two incoming feeders and one buscoupler breaker into a panel configuration.

The breaker control can be used for one or more point of control (remote, central and/or local). For the panel configuration, two automatic functions are optional:

- **Load Transfer**
The load transfer function secures the electrical power supply to the loads connected to a busbar or part of a busbar which is not fed any more because the incoming feeder or the buscoupler breaker has been tripped by under-voltage.
When the central mode becomes active, the control mode value from the remote panel will be taken over, where after the operator can control the auto/manual control mode from the incoming feeders or buscoupler breaker dialogue.
The load transfer will be performed only into central mode by closing an incoming feeder or buscoupler breaker as soon as transfer conditions are met.
- **Opening Breaker**
The opening breaker function opens down stream one of the two incoming feeders or the buscoupler breaker after a tuneable time-out, avoiding parallelism for a longer time. Which of the two incoming feeders or buscoupler breaker to open is chosen on forehand by the operator (default setting is the buscoupler breaker). The opening breaker function is only active in central mode when all following conditions are met:
 - *the two incoming feeders and buscoupler breaker are closed during a tuneable time-out*
 - *none of the two incoming feeders or buscoupler breaker is in the racked-out position*

9. MOTOR CONTROL

The motor control can be used for one or more point of control (remote, central and/or local). The motor control is accomplished with a basic section (status conditioning and supervision, command supervision) and a number of optional additional functions like:

- automatic start mode
- forward/backward control
- load shedding
- re-acceleration
- running hours calculation

For each motor with the load shedding option, the operator from central point of control is able to:

- change priority (from 1..20)
- change group (smallest sheddable unit within a priority)
- enable or disable load shedding functionality

For each motor with the re-e-acceleration option, the operator from central point of control is able to:

- maximum shut-off time
- re-acceleration priority (from 1..20)
- inhibit or enable re-acceleration functionality

10. TAP CHANGER CONTROL

The tap changer control can be used for one or more point of control (remote, central and/or local). The tap changer control is accomplished with a basic section (status conditioning and supervision, command supervision) and a number of optional additional functions like:

- count number of tapchanger operations

The purpose of the function “On-Load Tap Changer Control (OLTC)” is to maintain a constant voltage at the low voltage side of the EHV power transformers. In some, rare, cases the voltage at the high voltage side is to be regulated. The function allows for the latter case as well. The tap changer control consists of two modules, one for single control of tap changers and for the parallel operation of transformers. Main features of the tap changer control are:

- checking and changing of important parameters from the ABB Advant Station Operator Station
- blocking of controls if voltage or current limitations are violated (blocking on conditions of circuit breakers, disconnectors, communication and tap changer position)
- line drop compensation
- constant or inverse relationship between the voltage deviation from the setpoint and the time delay before operating the tap changer

10.1. Operating Principles

The basic input for the tapchanger control function is the phase-to-phase voltage on the low voltage side of the transformer and the three phase currents at the low voltage side.

The measured voltage ($U_B = U_{L1} - U_{L3}$) is used for the voltage control and the protection of the tap changer whereas the phase currents I_{L1} , I_{L2} and I_{L3} are used for protection of the tap changer only. The setpoint voltage is denoted as U_S and the tap changer will operate as soon as the difference between U_S and U_B is too large. A voltage/time characteristic is included in the basic tap changer control function to determine the delay time before operating the tap changer. The tap changer operation is prevented under conditions which would lead to excessive wear and damages of the tap changer.

The tap changer function operates when it receives a “raise” or a “lower” command. The function expects an increase in tap changer position after a “raise” command. The tap changer control does not send more than one command at the same time. The change of position is verified and the blocking conditions are tested by the tap changer control before a consecutive command is sent to the tap changer.

The duration of the output pulse from the tap changer control to raise or lower the tap changer is adjustable. Default setting is 1 second. The number of operations of the tap changer is counted by two counters which may be set and reset by the operator. They can for example be used to count the total number of operations and the number of operations since the maintenance overhaul.

10.2. On-Load Parallel Control

The parallel control function for parallel control of OLTC's is designed to operate together with the single tap changer control as described before.

The parallel control uses the master/slave principle, meaning that the regulator of one transformer is active while the tap changer of the other transformer follows the changes of the first (master) transformer. The operator determines the control mode of every transformer or pair of transformers. This mode can be manual, automatic independent and automatic master/slave.

When tap changer position of parallel tap changers differs more than 1 step an alarm is generated immediately. When the difference is one step an alarm will be generated.



Document no. 3BNL ITC 004 RB10

ABB Systemen BV
Department NLSYS/YAV-I
P.O. Box 2714 - 3000 CS Rotterdam
Marten Meesweg 5 - 3068 AV Rotterdam
Telephone: +31 10 407 86 22
Telefax: +31 10 456 17 60