



中国国家强制性产品认证证书

证书编号: 2010010303393101

委托人名称、地址

ABB STOTZ-KONTAKT GmbH
Hauptstrasse 14-16, D-78132 Hornberg, Germany

生产者(制造商)名称、地址

ABB STOTZ-KONTAKT GmbH
Hauptstrasse 14-16, D-78132 Hornberg, Germany

生产企业名称、地址

ATM Electronics Ltd.
Varna Str. 1 2850 Petrich Bulgaria

产品名称和系列、规格、型号

电子式时间继电器

CT-xxE; Ui:300V; Uimp:4kV; AC-15:Ue/le:AC230V/3A; DC-13:Ue/le:DC24V/2A; lth:4A; 外壳防护等级: IP20. 型号解释详见附件

产品标准和技术要求

GB/T14048.5-2017

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求, 特发此证。

发证日期: 2019年05月05日 有效期至: 2019年12月16日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2010年02月24日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2010010303393101

NAME AND ADDRESS OF THE APPLICANT

ABB STOTZ-KONTAKT GmbH
Hauptstrasse 14-16, D-78132 Hornberg, Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB STOTZ-KONTAKT GmbH
Hauptstrasse 14-16, D-78132 Hornberg, Germany

NAME AND ADDRESS OF THE FACTORY

ATM Electronics Ltd.
Varna Str.1 2850 Petrich Bulgaria

PRODUCT NAME, MODEL AND SPECIFICATION

Electronic Timer Relays

CT-xxE; Ui:300V; Uimp:4kV; AC-15:Ue/le:AC230V/3A; DC-13:Ue/le:DC24V/2A; Ith:4A; Levels of Protection: IP20. See the Appendix for type explanation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.05,2019

Valid until: Dec.16,2019

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Feb.24,2010

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE