

<b>ABB Drives</b>			<b>TRANSFORMER SELECTION</b>			<b>3AXD10000017152</b>		
			<b>Technical Description</b>					
Dept.	Project	Status	Date	Author	Status	Revision	Page	
	DRIVES		17.Dec 2010	RANTA KARI		A	1 / 2	

## Transformer computing within DriveSize

DriveSize will select a transformer based on base loads of motors but you must use your application knowledge to verify the selection is based on relevant inputs. You may let DriveSize to select a transformer if motor(s) and drive(s) selections are done already. Transformer load is then calculated from all supply unit types (DSU, TSU, ISU) or from single drives. But you may override values computed by DriveSize by typing in the correct transformer load(s) as required fundamental power.

Transformers types are: Dry and Oil-immersed. With "Auto selection" anyway Dry is preferred. The winding number of transformer has to match the pulse number of drive or supply units.

Windings	pulse #
2	6
3	12

DriveSize will compute and show the sinusoidal apparent power from base loads assuming they are present concurrently. It is called "**Fundamental power**" and divided in two parts DSU/TSU load and ISU load if present.

The following equations are used to compute fundamental powers. The first part collects the sum of positive powers and adds the losses of DSU/TSU/ISU. Basically this can be computed from positive motor base powers considering losses and considering number of motors and number of inverters. The second part of equation takes care of big single negative powers.

Fundamental power for DSU load and ISU loads individually:

$$S_{load\_DSU} = 1.05 \cdot \max\left(\sum\left(\frac{P_{cont,mot,LSU} + P_{loss,LSU}}{\cos\varphi}\right), \frac{|P_{cont,gen\_mostnegative}|}{\cos\varphi}\right)$$

$$S_{load\_ISU} = 1.05 \cdot \max\left(\sum\left(\frac{P_{cont,mot,ISU} + P_{loss,ISU}}{\cos\varphi}\right), \frac{|P_{cont,gen\_mostnegative}|}{\cos\varphi}\right)$$

The  $\cos\varphi$  values are

DSU  $\cos\varphi=0.98$

TSUs  $\cos\varphi =$  minimum value of 0.98 and MotorVoltage/Secondary voltage

4Q and ISUs  $\cos\varphi = 1$ .

Then the total fundamental power is computed.

$$S_{load} = S_{load\_DSU} + S_{load\_ISU}$$

And then an auxiliary variable  $\alpha$ , which together with different harmonics pattern will determine the derating of transformer.

$$\alpha = \min\left(\frac{0.04 * S_{load} (kVA)}{U_{sec.voltage} (V)}, 0.2\right), \text{ this will have values between } 0.02 \dots 0.2$$

<b>ABB Drives</b>		<b>TRANSFORMER SELECTION</b>			<b>3AXD10000017152</b>		
		<b>Technical Description</b>					
Dept.	Project	Status	Date	Author	Status	Revision	Page
	DRIVES		17.Dec 2010	RANTA KARI		A	2 / 2

If there is DSU/TSU supply units then for DSU/TSU load

$$k_{DSU} = \sqrt{\frac{1+a}{1.11+a*4}}, \text{ this will vary between } 0.926\dots 0.79$$

If there are 4Q ISU supplies then for ISU load

$$k_{ISU} = \sqrt{\frac{1+a}{1.01+a*1,12}}, \text{ this will vary between } 0.99\dots 0.9860$$

The final derating divider is computed based on weights of loads

$$k = \frac{k_{DSU} * S_{load\_DSU} + k_{ISU} * S_{load\_ISU}}{S_{load}}$$

Finally proposed transformer nominal power has to meet following criteria.

$$S_n \geq \frac{S_{load}}{k}$$

Selection criteria's are that nominal frequency, winding number match, Secondary Voltage and Primary voltage are high enough. DriveSize will refuse to select transformer if DSU/TSU/ISU are representing different pulse numbers.

The ambient derating for transformers is considered too.

**The transformers found with DriveSize are within ABB made on locations:**

Oil transformers: ABB Elektrik San. A.S. 34776 Istanbul / Turkey

**CTMP 12 H\_200-500 200kVA**

**CTMP 24 H\_200-500 200kVA 24kV**

.

**CTMP 24 H\_1000-500 1000kVA 24kV**

.

**CTMP 24 H\_4000-500 4000kVA 24kV**

Dry type transformrs: ABB Power Technology at Zaragoza, Spain and others

**DTE 160 A8S 160kVA**

.

**DTE 1000 A8S 1000kVA**

.

**DTE 7500 A8S 7500kVA**