



TYPE APPROVAL CERTIFICATE

Certificate No:
TAE00000ES
Revision No:
3

This is to certify:

That the Circuit Breaker

with type designation(s)

S800S..., S800P, S803-SCL-SR, S803S-SCL, S800-AUX, S800-AUX/ALT

Issued to

**ABB Switzerland Ltd. Low Voltage Products
Schaffhausen, SH, Switzerland**

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Issued at **Hamburg** on **2023-10-24**

for **DNV**

This Certificate is valid until **2028-12-31**.

DNV local unit: **Augsburg**

Approval Engineer: **Harald Amberger**

.....
Oddvar Deinboll
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

S800S... / S800P... / S804U-UCZ Miniature circuit breaker
 S803S-SCL Short circuit current limiter
 S803S-SCL-SR Self-resetting short circuit limiter

	S800S	S800P	S804U-UCZ	S803S-SCL	S800-SCL-SR
Ratings acc. IEC 60947-2					
Insulation voltage U_i	V	AC 690	AC 690	DC 1500	AC 690
Impulse withstand voltage U_{imp}	kV	8	6	8	
Current I_e (30°C)*	A	10 - 125	63 - 125	10 - 80	32, 63, 125 32, 63, 100
Tripping characteristics		B, C, D, K	B, C, D, K	Z	--
Number of poles		1 - 4	1 - 4	4 (in series)	3 1, 2, 3
Operational voltage U_e	V	AC 400/690	AC 240/415	DC 600	AC 400/690
Frequency f	Hz	50/60	50/60	DC	50/60
Ultimate short-circuit cap. I_{cu}					
AC 240/415 V	kA	50	50	10 (DC600V)	100 (AC400V)
AC 254/440 V	kA	30	--	--	100 (AC440V)
AC 400/690 V (up to 80 A)	kA	6	--	--	50 (AC690V)
AC 400/690 V (100 - 125 A)	kA	4,5	--	--	50 (AC690V)
Service short-circuit cap. I_{cs}		100 % I_{cu}			
AC 240/415 V	kA	40	40	10 (DC600V)	
AC 254/440 V (up to 80 A)	kA	22,5	--	--	
AC 254/440 V (100 - 125 A)	kA	15	--	--	
AC 400/690 V (up to 80 A)	kA	4	--	--	
AC 400/690 V (100 - 125 A)	kA	3	--	--	
* (40°C) Tripping characteristics K Further ratings and correction factors for 45°C acc. manufacturer documentation.					

S800-AUX Auxiliary contact
 S800-AUX/ALT Combined auxiliary and signal contact

	S800-AUX	S800-AUX/ALT
Ratings acc. IEC 60947-5-1		
Insulation voltage U_i	V	AC 690
Impulse withstand voltage U_{imp}	kV	6
Utilisation Categories	AC15 400V/2 A, AC15 240V/6 A DC13 250/0.55 A, DC13 125 V/1.1 A DC13 60 V/2 A, DC13 24 V/4 A	
Number of contacts	2xAUX	1xAUX, 1xAUX/ALT
Contact function	Changeover	
Further ratings and mounting location acc. manufacturer documentation.		

Application/Limitation

Operating instruction of the manufacturer to be observed

Type Approval documentation

Test reports:

Test report 06-IK-0094.01 from Swiss Testing, acc. to IEC 60947-2:2003 dated 27.09.2006.
ABB test reports nos. P1639E dated 05.03.2007, P1640E dated 06.03.2007, P1641E dated 07.03.2007
P1642E dated 12.03.2007, P1643E dated 14.03.2007, P6239 dated 05.05.2023
CB Test Certificate CH-2848 from Electrosuisse, for Circuit Breaker, dated 2005-06-24.
CB Test Certificate CH-2988 from Electrosuisse, for Auxiliary/Signal contacts to circuit breakers series S800, dated 2005-11-29.
CB Test Certificate BE-11090 from SGS Belgium N.V. for Circuit Breaker, dated 2023-04-28.
Test report 04-IK-0300.01 from Swiss Testing, acc. to IEC 60947-2:2003 dated 07.06.2005.
Test report 04-IK-0301.10 from Swiss Testing, acc. to IEC 60947-5-1:2003 and 2004, dated 07.06.2005.
Vibration Test from ABB acc. to IEC 60068-2-6 dated 20.06.2006
Damp Heat Test from ABB acc. to IEC 60068-2-30 dated 20.06.2006
Dry Heat Test from ABB acc. to IEC 60068-2-2 dated 20.06.2006
Test report P1524 from ABB acc. to IEC 60947-2 dated 11.07.2006
Test report P2649E from ABB acc. to IEC 60947-2 dated 03.08.2011
Test report P2997E from ABB acc. to IEC 60947-4-1 and IEC 60947-2 dated 08.06.2011
Test report 63152401-00 from SGS acc. to IEC 60947-2 dated 12.09.2020

Tests carried out

IEC 60947-2 sequence I, II & III and annex H, IEC 60947-5-1
Vibration, humidity, dry heat, cold (+5°C) and inclination tests.

Marking of product

ABB - type designation - rated voltage - rated insulation voltage - breaking capacity.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE