



NAVAL SHIPS

TYPE APPROVAL CERTIFICATE

N.MIL-ELE2644021CS

This is to certify that the product below is found to be in compliance with the applicable requirements of the RINA Type Approval system.

Description	Circuit breaker
Type	Tmax XT Series: XT1/ML, XT2/ML, XT3/ML, XT4/ML, XT5/ML, XT6/ML, XT7/ML
Applicant	ABB S.p.A – ABB Sace Division Via Pescaria 5 24123 Bergamo Italy
Manufacturer	ABB S.p.A. – ABB Sace Division Via Enrico Fermi, 14 03100 Frosinone Italy
Testing Standards	RINA Rules for the Classification of Ships, Pt. C, Ch. 2,Sec.8

Issued in **Genova** on **November 24, 2021**

This certificate is valid until **November 24, 2026**

RINA Services S.p.A.

Luigi Benedetti





NAVAL SHIPS

TYPE APPROVAL CERTIFICATE

N.MIL-ELE264421CS

Product Description

• Circuit Breaker type Tmax XT1

Version	XT1B/ML			XT1C /ML			XT1N/ML			XT1S/ML			XT1H/ML		
Rated current In [A]	16-160			16-160			16-160			16-160			16-160		
Release type	TMD														
Voltage Ue V ac	230	440	690	230	440	690	230	440	690	230	440	690	230	440	690
Icu [kA]	25	15	3	40	25	4	65	36	6	85	50	8	100	65	10
Ics [kA] % Icu	100	75	100	100	50	100	75	50	75	75	50	50	75	50	50
Frequency [Hz]	50-60														
T amb [°C]	40														
Voltage V dc	250(*)	500(**)	250(*)	500(**)	250(*)	500(**)	250(*)	500(**)	250(*)	500(**)	250(*)	500(**)	250(*)	500(**)	250(*)
Icu [kA]	18	18	25	25	36	36	50	50	70	70	70	70	70	70	70
Ics [kA] % Icu	100	100	100	100	100	100	100	100	100	100	100	100	75	75	75

(*) 2P in series ; (**) 3P in series

• Circuit Breaker type Tmax XT2

Version	XT2N/ML			XT2S/ML			XT2H/ML			XT2L/ML			XT2V/ML		
Rated current In [A]	20-160			20-160			20-160			20-160			20-160		
Release type	TMA, TMD, MF, MA Ekip LSI, Ekip I, Ekip LSI, Ekip LSI, Ekip G LSI, Ekip N LSI, Ekip M-LIU														
Voltage Ue V ac	240	440	690	240	440	690	240	440	690	240	440	690	240	440	690
Icu [kA]	65	36	10	85	50	12	100	65	15	150	100	18	200	150	20
Ics [kA] % Icu	100	100	100	100	100	100	100	100	100	100	100	75	100	100	75
Frequency [Hz]	50-60														
T amb [°C]	40														
Voltage V dc	250(*)	500(**)	250(*)	500(**)	250(*)	500(**)	250(*)	500(**)	250(*)	500(**)	250(*)	500(**)	250(*)	500(**)	250(*)
Icu [kA]	36	36	50	50	70	70	85	85	100	100	100	100	100	100	100
Ics [kA] % Icu	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100

(*) 2P in series; (**) 3P in series

• Circuit Breaker type Tmax XT3

Version	XT3C/ML			XT3N/ML			XT3S/ML		
Rated current In [A]	100 A to 200 A with release MA								
Release type	60 A to 250 A with release TMD , TMG								
Voltage Ue [Vac]	240	440	690	240	440	690	240	440	690
Icu [kA]	40	20	4	50	25	5	85	40	6
Ics [kA]	30	15	3	37.5	19	3	42.5	20	3
Frequency [Hz]	50-60								
T amb [°C]	40								
Voltage V dc				250 (*)	500 (**)	250 (*)	500 (**)		
Icu [kA]				36	36	50	50		
Ics [kA] % Icu				36	36	38	38		





NAVAL SHIPS

TYPE APPROVAL CERTIFICATE

N. MIL-ELE264421CS

• Circuit Breaker type Tmax XT4

Version	XT4N/ML			XT4S/ML			XT4H/ML			XT4L/ML			XT4V/ML		
Rated current In [A]	32-250			32-250			32-250			32-250			32-250		
Release type	TMA, TMD, MA Ekip LS/I, Ekip I, Ekip LSI, Ekip LSIG, Ekip G LS/I, Ekip N LS/I, Ekip M-LIU														
Voltage [V]	230	440	690	230	440	690	230	440	690	230	440	690	240	440	690
Icu [kA]	65	36	10	85	50	12	100	65	15	150	100	20	200	150	25
Ics [kA] % Icu	100	100	100	100	100	100	100	100	100	100	100	100	100	100	75
Frequency [Hz]	50-60 Hz														
T amb [°C]	40°C														
Voltage V dc	250(*)	500(*)	250(*)	500(*)	250(*)	500(*)	250(*)	500(*)	250(*)	500(*)	250(*)	500(*)	250(*)	500(*)	250(*)
Icu [kA]	36	36	50	50	70	70	85	85	100	100	100	100	100	100	100
Ics [kA] % Icu	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100

(*) 2P in series

• Circuit Breaker type Tmax XT7 / S H L and XT7M / S H L

Version	XT7S/ML				XT7H/ML				XT7L/ML			
Rated current In [A] Ith	800 / 1000 / 1250 /1600											
Release type	Ekip DIP LS/I, Ekip DIP LIG, Ekip DIP M-I, EKIP G-LS/I											
Voltage [V] Ue	220	380	440	690	220	380	440	690	220	380	440	690
	240	400			240	400			240	400		
		415				415				415		
Icu [kA]	85	50	50	30	100	70	65	42	200	120	100	50
Ics [kA] % Icu	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	75%
Icw [kA] 1 sec	20											
Frequency [Hz]	50-60 Hz											
T amb [°C]	40°C											

Rated service short circuit breaking capacity (Ics)

Rated ultimate short circuit breaking capacity (Icu)

Rated short-time withstand current (Icw)

For T ambient = 45°C, thermal – magnetic release must be derated in accordance with the following table:

XT1 /ML			XT2 /ML			XT3 /ML			XT4 /ML		
In [A]	MIN [A]	MAX [A]	In [A]	MIN [A]	MAX [A]	In [A]	MIN [A]	MAX [A]	In [A]	MIN [A]	MAX [A]
50	33,9	48,4	20	13,5	19,3	63	43	61	25	17	24
63	42,7	61	25	16,8	24,0	80	54	77	32	22	31
80	54,2	77	32	21,6	30,8	100	68	97	40	27	39
100	67,8	97	40	27,0	38,5	125	85	121	50	34	48
125	84,7	121	50	33,7	48,2	160	108	155	63	43	61
160	108,4	155	63	42,5	60,7	200	136	194	80	54	77
			80	54,0	77,1	250	169	242	100	68	97
			100	67,5	96,4				125	85	121
			125	84,3	120,5				160	108	155
			160	107,9	154,2				200	136	194
									225	152	218
									250	169	242





NAVAL SHIPS

TYPE APPROVAL CERTIFICATE

N. MIL-ELE264421CS

Reference documents (21-06 2017):

SACE Tmax XT Technical catalogue: doc. n. 1SDC210033D0202

CB test Certificate: SE-72324A1/M1, SE-70707A1, CN31818, SE-71130A1**Reference documents (29/11/2018):**

SACE Tmax XT Technical catalogue: PRELIMINARY - 06/2018

CB test Certificates:

IEC 60947-2:2016 : SE-90445 (12.04.2018); SE-90444 (12.04.2018)

Certificate of conformity: IEC 60947-2: (2016) and IEC 60947-2 (2017) : docs. n. IT18.113 and IT18.114 (2018.04.18);

Test Reports:

IEC 60947-2:2016 docs. n. 1806441STO-001_(2018.03.27); doc. n. 1806443STO-001_(2018.03.27)

Climatic tests docs. LBRP 16568_00 rev. 0. (2018.06.08); LBRP 16569_00 rev. 0 (2018.05.28); LBRS 16920_00 rev.0, (25.07.2018)

Electromagnetic compatibility:

IEC 60947-2 Annex J and F: doc. 200019647UDI-EMC (15.02.2018)

IEC 60947-2 Annex N: doc. 200019647UDI-EMVa (19.02.2018)

IACS Standard: doc. 200019647UDI-EMCb (15.02.2018); IACS Standard: doc. 200019647UDI-EMCd (15.02.2018)

Mechanical tests: Inclination doc. LBRP 16918_00 rev. 0 (25.06.2018); Inclination doc. LBRP 16918/01 rev. 0 (25.06.2018)

Vibrations doc. LBRP 16917_00 rev. 0 (13.09.2018); Vibrations doc. LBRP 16917/01 rev. 0 (13.09.2018)

Certificate update: 01/09/2020**Circuit Breaker type Tmax XT5 / N_S_H_L and XT5 / V_X**

Rated Uninterrupted current, In	A	250, 320, 400, 500, 630					
Poles		3, 4					
Rated service Voltage, Ue	AC 60Hz	240 to 690					
	DC	250 to 750					
Rated insulation voltage, Ui	V	1000					
Rated impulse withstand voltage, Uimp	kV	8					
Version		Fixed, Withdrawable, Plug-in					
Breaking capacities (IEC 60947-2)		N/ML	S/ML	H/ML	L/ML	V/ML	X/ML
Rated ultimate short-circuit breaking capacity, Icu AC		Icu					
Icu @ Ue 220-230-240 Vac 50 / 60 Hz	kA	70	85	100	150	200	200
Icu @ Ue 380 Vac	kA	36	50	70	120	200	200
Icu @ Ue 415 Vac	kA	36	50	70	120	200	200
Icu @ Ue 440 Vac	kA	36	50	65	100	180	200
Icu @ Ue 500 Vac	kA	25	30	50	85	150	150
Icu @ Ue 525 Vac	kA	25	30	50	85	100	120
Icu @ Ue 690 Vac	kA	20	25	40	70	80	100
Rated service short-circuit breaking capacity, Ics AC	kA	Ics = % of Icu					
Ics @ Ue 220-230-240 AC 50 / 60 Hz	kA	100%	100%	100%	100%	100%	100%
Ics @ Ue 380 Vac	kA	100%	100%	100%	100%	100%	100%
Ics @ Ue 415 Vac	kA	100%	100%	100%	100%	100%	100%
Ics @ Ue 440 Vac	kA	100%	100%	100%	100%	100%	100%
Ics @ Ue 500 Vac	kA	100%	100%	100%	100%	100%	100%
Ics @ Ue 525 Vac	kA	100%	100%	100%	100%	100%	100%
Ics @ Ue 690 Vac	kA	100%	100%	75%	50%	50%	50%
Ics @ Ue 690 Vac up to In = 500A	kA	100%	100%	100%	100%	100%	100%
Ref. ambient temperature	40 °C						
Utilization Category	A (In > 500A), B (In ≤ 500A)						
Rated short-time withstand current (Icw) Cat. B	6 kA (1 sec) for XT5 630 frames up to In=500A; 5 kA (1 sec) for XT5 400 frames						
Suitable for Insulation	Yes						
Trip units for power distribution	TMD / TMA; Ekip Dip ; Ekip Touch						
Trip units for motor protection	MF / MA; Ekip Dip Ekip Touch						
Trip units for generator protection	TMG; Ekip Dip; Ekip Touch						

Rated service short circuit breaking capacity (**Ics**)Rated ultimate short circuit breaking capacity (**Icu**)Rated short-time withstand current (**Icw**)



NAVAL SHIPS

TYPE APPROVAL CERTIFICATE

N. MIL-ELE264421CS

Rated ultimate short-circuit breaking capacity, Icu DC		N/ML	S/ML	H/ML	L/ML	V/ML	X/ML
Icu@ Ue 250Vdc (2 poles in series)	kA	25	35	50	70	85	100
Icu@ Ue 500Vdc (2 poles in series)	kA	25	35	50	70	85	100
Icu@ Ue 750Vdc (3 poles in series)	kA					85	100
Rated service short-circuit breaking capacity, Ics DC	kA						
Ics@ Ue 250Vdc (2P in series)	kA	100%	100%	100%	100%	100%	100%
Ics@ Ue 500Vdc (2P in series)	kA	100%	100%	100%	100%	100%	100%
Ics@ Ue 750Vdc (3P in series)	kA					100%	100%
Trip Unit	TMD / TMA ; TMG						

Test reports / Certificates:

Intertek Semco test report n. 1817203STO-001 (10 April, 2020) acc. to IEC 60947-2:2016
Intertek Semco CB Test Certificate SE-101368 (09 June, 2020) acc. to IEC 60947-2:2016
Intertek Semco CB Test Certificate SE-101370 (09 June, 2020) acc. to IEC 60947-2:2016
Intertek Semco CB Test Certificate SE-101369A1 (24 June, 2020) acc. to IEC 60947-2:2016
Intertek Semco CB Test Certificate SE-101371A1 (24 June, 2020) acc. to IEC 60947-2:2016
UL International Italia test report n. 19-4788844257-1-1-0-EMC (2019.03.29) acc. to IEC 60947-2:2016
UL International Italia test report n. 19-4788844257-2-1-0-EMC (2019.03.29) acc. to IEC 60947-2:2016
UL International Italia test report n. 19-4788844257-3-1-0-EMC (2019.03.29) acc. to IEC 60947-2:2016
UL International Italia test report n. 19-4788844257-4-1-0-EMC (2019.03.29) acc. to IEC 60947-2:2016
UL International Italia test report n. 19-4788923674-2-1-0-EMC (2019.03.29) acc. to LR/RINA/DNV/ABS/BV
UL International Italia test report n. 19-4788923674-3-1-0-EMC (2019.03.29) acc. to LR/RINA/DNV/ABS/BV
UL International Italia test report n. Rel19-4788844257-1-0-EMC (2019.03.29) acc. to IEC 60947-2:2016
UL International Italia test report n. Rel19-4788923674-1-0-EMC (2019.03.29) acc. to IEC 60947-2:2016
Intertek Italia test report n. 200026776UDI-EMC (2020.07.09) Acc to IEC 60092-504:2016 (1 to 6 GHz immunity)
ABB SACE Division test report (Climatic) n. LBRP18334/00 rev.0, LBRP18335/00 rev.0, LBRP18336/00 rev.0, LBRP18337/00 rev.0
ABB SACE Division test report (Vib + Shock) n. LBRP18338/00 rev.0, LBRP18338/01 rev.0, LBRP18339/00 rev.0, LBRP18339/01 rev.0
LBRP 18340/00 rev.0, LBRP18340/01 rev.0, LBRP18341/00 rev.0, LBRP18341/01 rev.0, LBRP18342/00 rev.0, LBRP18343 rev.0, LBRP18344/00 rev.0

For T ambient = 45°C thermal-magnetic release must be derated in accordance with the following table:

XT1/ML			XT2/ML			XT3/ML			XT4/ML			XT5/ML		
In [A]	MIN [A]	MAX [A]	In [A]	MIN [A]	MAX [A]	In [A]	MIN [A]	MAX [A]	In [A]	MIN [A]	MAX [A]	In [A]	MIN [A]	MAX [A]
50	33,9	48,4	20	13,5	19,3	63	43	61	25	17	24	320	215	310
63	42,7	61	25	16,8	24	80	54	77	32	22	31	400	275	390
80	54,2	77	32	21,6	30,8	100	68	97	40	27	39	500	340	485
100	67,8	97	40	27	38,5	125	85	121	50	34	48	630	430	625
125	84,7	121	50	33,7	48,2	160	108	155	63	43	61			
160	108,4	155	63	42,5	60,7	200	136	194	80	54	77			
			80	54	77,1	250	169	242	100	68	97			
			100	67,5	96,4				125	85	121			
			125	84,3	120,5				160	108	155			
			160	107,9	154,2				200	136	194			
									225	152	218			
									250	169	242			

Note:

This certificate annuls and replaces the previous n. ELE226620CS issued on September 01, 2020





NAVAL SHIPS

TYPE APPROVAL CERTIFICATE

N.MIL-ELE264421CS

Certificate update: 22/04/2021

• **Circuit Breaker type Tmax XT6/ N _S_ H_**

Rated Operational current, In	A	600, 630, 800, 1000		
Poles		3, 4		
Rated service Voltage, Ue AC 50 - 60Hz	V	690		
Rated insulation voltage, Ui	V	1000		
Rated impulse withstand voltage, Uimp	kV	8		
Version		Fixed, Withdrawable,		
Breaking capacities (IEC 60947-2)		N/ML	S/ML	H/ML
Rated ultimate short-circuit breaking capacity, Icu AC		Icu		
Icu @ Ue 220, 230, 240 Vac	kA	70	85	100
Icu @ Ue 380, 400, 415 Vac	kA	36	50	70
Icu @ Ue 440 Vac	kA	30	45	50
Icu @ Ue 500 , 525 Vac	kA	25	35	50
Icu @ Ue 660, 690 Vac	kA	20	22	25
Rated service short-circuit breaking capacity, Ics AC		Ics= % of Icu		
Icu @ Ue 220, 230, 240 Vac	kA	100%	100%	100%
Icu @ Ue 380, 400, 415 Vac	kA	100%	100%	100%
Icu @ Ue 440 Vac	kA	100%	100%	100%
Icu @ Ue 500, 525 Vac	kA	100%	100%	100%
Icu @ Ue 660, 690 Vac	kA	100%	100%	100%
Ref. ambient temperature		40 °C		
Selectivity Category		A (In = 1000 A), B (In =600, 630, 800A)		
Rated short-time withstand current (Icw)		10 kA / Is Cat. B		
Suitable for Insulation		Yes		
Trip units for power distribution		TMA; Ekip Dip LSIG; LIG; LS-I		
Trip units for motor protection		Ekip M DIP I; Ekip M DIP LIU		
Trip units for generator protection		Ekip G Dip LS-I		

Rated ultimate short-circuit breaking capacity, Icu DC		N/ML	S/ML	H/ML
Icu@ Ue 250 Vdc (2 poles in series)	kA	35	50	70
Icu@ Ue 500 Vdc (2 poles in series)	kA	20	35	50
Icu@ Ue 750 Vdc (3 poles in series)	kA	18	24	36
Rated service short-circuit breaking capacity, Ics DC				
Ics@ Ue 250Vdc (2P in series)	kA	100%	50%	50%
Ics@ Ue 500Vdc (2P in series)	kA	100%	50%	50%
Ics@ Ue 750Vdc (3P in series)	kA	100%	75%	50%
Trip Units		TMA		

XT6 TMA Rated current according to ambient temperature

T. amb (°C)	10		20		30		40		45		50		60		70	
In [A]	min	max	min	max	min	max	min	max	min	max	min	max	min	max	min	max
630	560	700	470	670	450	645	440	630	430	615	420	605	375	580	335	555
800	770	960	635	910	600	860	560	800	545	780	530	760	455	700	385	640

Certificate and Test Reports

CQC CB Test Certificate n. CN50672 _ IEC60947-2:2016 (Jul.14.2020)
 CQC Test report n. 00901-CB2019CQC-087756 _ IEC60947-2:2016 (2020.05.28)
 ABB Test report n. LBRP18355_00_inclination (XT6 EKIP LS-I) (2019.11.26);
 ABB Test report n. LBRP18749_00_vibration (XT6 EKIP DIP LSIG W) (2021.02.05)
 ABB Test report n. LBRP18750_00_shock (XT6 W EKIP DIP LSIG) (2021.02.08)
 ABB Test report n. LBRP19307_00_climatic (XT6 EKIP DIP LS-I) (2020.09/22)
 UL International Italia Test report n. 19-4788844257-4-1-0-EMC_XT6_4P_Ekip Dip LS_I
 UL International Italia Test report n. 19-4788844257-5-1-0-EMC_XT6_4P_Ekip Dip LSIG
 UL International Italia Test report n. 19-4788923674-4-1-0-EMC_XT6_4P_Ekip Dip LS_I
 UL International Italia Test report n. 19-4788923674-5-1-0-EMC_XT6_4P_Ekip Dip LSIG
 INTERTEK Test report n. 200026776UDI-EMC (immunity 1 to 6 GHz)





NAVAL SHIPS

TYPE APPROVAL CERTIFICATE

N. MIL-ELE264421CS

Circuit Breakers type Tmax XT4/ N_S_H_L_V_X

3, 4 poles; Service voltage $U_e = 690V$; Rated insulation voltage $U_i = 1000V$; Rated input withstand voltage $U_{imp} = 8kV$

Version	XT4N/ML			XT4S/ML			XT4H/ML			XT4L/ML			XT4V/ML			XT4X/ML		
Rated current In [A]	16-250			16-250			16-250			16-250			16-250			16-250		
Trip units	TMA, TMD, MA, Ekip LS/I, Ekip I, Ekip LSI, Ekip LSIG, Ekip G LS/I, Ekip N LS/I, Ekip M-LIU, Ekip DIP, Ekip Touch, Ekip M DIP, Ekip M Touch, Ekip HI-Touch, Ekip G DIP, Ekip G Touch																	
Voltage [Vac]	240	440	690	240	440	690	240	440	690	240	440	690	240	440	690	240	440	690
Icu [kA]	65	36	10	85	50	12	100	65	15	150	100	20	200	150	50(*)	200	200	100
Ics [kA] % Icu	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100(**)	100	100	100(**)
Selectivity Cat.	A			A			A			A			A			A		
Frequency [Hz]	50-60 Hz																	
Icm [kA]	143	75.6	17	187	105	24	220	143	30	330	220	40	440	330	52.5	440	440	440
T amb [°C]	40°C																	

Voltage U_e [Vdc]	250		500		250		500		250		500		250		500		500	750
	2P Series		2P Series		2P Series		2P Series		2P Series		2P Series		2P Series		2P Series		3P Series	
Icu [kA]	36	36	50	50	70	70	85	85	100	100	100	100	100	100	100	100	100	70
Ics [kA] % Icu	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
Trip units	TMD /TMA																	

(*) For $I_n \leq 32A$, $I_{cu} = 25kA$ / $I_{cs} = 20kA$

(**) $I_{cs} = 100\% I_{cu}$ up to 250A with EF, ES and rear terminals, $I_{cs} = 25kA$ when any other terminals are used and $I_n > 200A$

Certificates and test reports:

Intertek CB Test Certificate _ IEC 60947-2:2016_n. SE-102367 (16.09.2020)

Intertek Test Report _ IEC 60947-2:2016_n. 2021273STO-001(30.07.2020)

Lovag Test Reports:

n. 1479 (2019.04.01)_EN 60947-2: 2017; n. 1480 (2019/04/04) EN 60947-2: 2017

ABB Test Reports:

LBRP 17282/00 (2018.11.22), LBRP 17283/00 (2018.11.14), LBRP 17284/00 (2019.06.06),

LBRP 17284/01 (2019.06.07), LBRP 17287/00 (2018.11.19), LBRP 17288/00 (2018.12.21),

LBRP 17289/00 (2019.06.06), LBRP 17289/01 (2019.06.07),

Shanghai Testing & inspection Institute for Electrical Equipment Test Reports:

ATR18-0160-2 (2019.01.08)_ GB/T 14048.2-2008;





NAVAL SHIPS

TYPE APPROVAL CERTIFICATE

N. MIL-ELE264421CS

Circuit Breaker type Tmax XT2

3, 4 poles; Service voltage $U_e = 690V$; Rated insulation voltage $U_i = 1000V$; Rated input withstand voltage $U_{imp} = 8kV$

Version	XT2N /ML			XT2S /ML			XT2H /ML			XT2L /ML			XT2V /ML		
Rated current I_n [A]	20-160			20-160			20-160			20-160			20-160		
Trip units	TMA, TMD, MA, Ekip LS/I, Ekip I, Ekip LSI, Ekip LSIg, Ekip G LS/I, Ekip N LS/I, Ekip M-LIU, Ekip DIP, Ekip Touch, Ekip M DIP, Ekip M Touch, Ekip HI-Touch, Ekip G DIP, Ekip G Touch														
Voltage U_e Vac	240	440	690	240	440	690	240	440	690	240	440	690	240	440	690
I_{cu} [kA]	65	36	10	85	50	12	100	65	15	150	100	18	200	150	20
I_{cs} [kA] % I_{cu}	100	100	100	100	100	100	100	100	100	100	100	75	100	100	75
Frequency [Hz]	50-60														
T_{amb} [°C]	40														
Voltage U_e Vdc	250(*)	500(**)	250(*)	500(**)	250(*)	500(**)	250(*)	500(**)	250(*)	500(**)	250(*)	500(**)	250(*)	500(**)	250(*)
I_{cu} [kA]	36	36	50	50	70	70	85	85	100	100	100	100	100	100	100
I_{cs} [kA] % I_{cu}	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
Trip units	TMD / TMA TMG														

(*) 2P in series; (**) 3P in series

Certificates and test reports:

Lovag Test Reports:

n. 1477 (2019.04.04)_EN 60947-2: 2017; n. 1478 (2019/04/05)_EN 60947-2: 2017

ABB Test Reports:

LBRP 17264/00 (2018.11.19), LBRP 17265/00 (2018.11.19), LBRP 17266/00 (2018.11.19), LBRP 17267/00 (2018.12.21), LBRP 17269/00 (2019.01.25), LBRP 17270/00 (2019.01.25), LBRP 17270/01 (2019.01.29)

Shanghai Testing & inspection Institute for Electrical Equipment Test Reports:

ATR18-0160-1 (2019.01.08)_ GB/T 14048.2-2008;

Note:

This certificate annuls and replaces the previous n. ELE226620CS001 issued on September 07, 2020

