



Test Report				Date of issue: 16.6.2015					
Customer:				Serial No.:					
Customer ref.:				Order No.:					
				Type: M3BP 160MLA 6					
				Product Code: 3GBP163410-ADK					
Rating:									
		V	Hz	kW	r/min	A	cos φ	Duty	
3-Motor		690	Y 50	7,5	980	8,8	0,78	S1	
Insul.cl.F		400	D 50	7,5	980	15,2	0,78	S1	
IP55		660	Y 50	7,5	977	9,1	0,80	S1	
		380	D 50	7,5	977	15,7	0,80	S1	
		415	D 50	7,5	981	14,8	0,77	S1	
		460	D 60	7,5	1182	13,5	0,76	S1	
Eff class IE3		50Hz : IE3-90,8(100%)-91,5(75%)-91,0(50%) 60Hz : IE3-91,4(100%)							
Resistance				Insulation resistance at 23 °C		Overload			
Line		Ambient: 21,8 °C		R > 2000 Mohm 1000 V		Curren 150 % 120s Torque 160 % 15s Speed 120 % 120s			
U1 - V1		0,7040 Ω							
U1 - W1		0,7012 Ω							
V1 - W1		0,7020 Ω							
				High-voltage test winding 2400 V		60 s			
Test	Torque [Nm]	Line U[V]	f[Hz]	Input I[A]	P1 [kW]	Output P2 [kW]	n[r/min]	cos φ	η [%]
No load test		400 D	50	7,3	0,26		1000	0,05	
Locked rotor test		89 D	50	14,9	0,59		0	0,26	
Thermal test (100% load	73,1	400 D	50	15,5	8,25	7,50	980	0,77	90,88
Partial load points:									
~75% load	55,1	400 D	50	12,6	6,23	5,69	986	0,71	91,33
~50% load	37,9	400 D	50	10,3	4,33	3,94	990	0,61	90,84
~25% load	19,0	400 D	50	8,3	2,28	1,98	995	0,40	86,83
Temperature rise at rated load.				[°C]	[K]	Method	Measurement method		
Stator winding :				30,6	1		1 Resistance		
Frame :				18,9	2		2 Thermometer		
Bearing D-end :				18,0	2		3 Thermocouples		
Ambient Temperature :				23	2				
These tests have been carried out on motor no. 3GV1110782960001, on date 2011-10-07 which is identical in electrical design with the above. Manufactured and tested in accordance with rules of IEC 60034-1 and IEC 60034-2-1. PLL determined from residual loss. On behalf of customer On behalf of manufacturer Date of test Tested by ABB AB, LV Motors, 721 70 Västerås, Sweden Telephone +46 (0)21 32 90 00 Telefax +46 (0)21 32 90 22									

Computer print-out valid without signature.