

Content

1.	DEVICE - REVISION RECORD - WHAT IS NEW?.....	1
1.1	HARDWARE	1
1.2	FIRMWARE.....	1
1.3	DEVICE.....	1
2.	CYBER SECURITY INFO	1
2.1	ABB RECOMMENDATION	1
3.	EDD (ELECTRONIC DEVICE DESCRIPTION)	2
3.1	SUPPORTED DEVICES	2
3.2	EDD VERSION RECORD - WHAT IS NEW?	2
3.3	REQUIREMENTS.....	2
3.4	INTERPRETER / COMPATIBILITY.....	2
4.	INSTALLATION AND CONFIGURATION.....	2
4.1	KNOWN PROBLEMS AND LIMITATIONS	2
4.2	GETTING HELP / FURTHER INFORMATION.....	2
4.3	HOW TO GET THE LATEST INFORMATION & SOFTWARE?	2

**) DTM500 Bundle Supplement Info is available on the data medium documentation or latest on www.abb.com/fieldbus. Enter here in the search field following No. "3KXD801500R3901".*

1. Device - Revision Record - What is new?

1.1 Hardware

Released Revision	Released Date	Remarks
01.00.00	Jan. 2015	First release

1.2 Firmware

Released Revision	Released Date	Remarks
143.01.01	Mar.2015	First release
143.01.02	Oct.2015	Improvements: <ul style="list-style-type: none"> • Z & S push button operation to be confirmed after HMI feed-back • Set PV to zero & Reset Bias operations via HMI menu Bugfixes: <ul style="list-style-type: none"> • Write prot. didn't block HMI editing • Default High alarm limit changed by 5.25 V to 5.4 V

1.3 Device

(Released Revision	Released Date	Remarks
01.00	Aug.2015	

2. Cyber Security info

2.1 ABB recommendation

A virus scanner shall be used on all PCs/Notebooks. McAfee VirusScan® Enterprise has been tested and qualified for this purpose.

3. EDD (Electronic Device Description)

3.1 Supported devices

2600T Series Pressure Transmitters 266 PdP-
HART 1-5 Volt

- Gauge Pressure Model 266HSH

→ latest information [field device protocol dependent]

→ latest info (download) [*device type dependent*]

- Driver description
- Software [*driver type dependent*]

3.2 EDD Version record - What is new?

Released Version (Dev Rev)	Released Date	Remarks
01 01	Jan. 2016	First release

3.3 Requirements

HART 7

3.4 Interpreter / compatibility

The EDD is released for:

- ABB DHH805
- Emerson AMS 11.5,
- Emerson HHT 475 V 3.8 and
- SDC625 V3.0.1.

4. Installation and configuration

Start your Frame application and follow the instructions.

4.1 Known problems and limitations

None

4.2 Getting help / further information

Help concerning the integration of the driver in the frame application can be found in the respective documentation of the frame application.

4.3 How to get the latest information & software?

The latest device driver Supplement Info & software (driver) is available on www.abb.com/fieldbus:

Driver 2600T(266-PdP) HART 1-5V

Pressure and Level Transmitter

3KXP002266R3901 Rev. A

**ABB has Sales & Customer Support
expertise in over 100 countries worldwide.**

<http://www.abb.com/measurement>

The Company's policy is one of continuous product improvement and the right is reserved to modify the information contained herein without notice.

Printed in the Fed. Rep. of Germany (08.2016)

© ABB 2016

3KXP002266R3901 Rev. A



Germany

ABB Automation Products GmbH
Borsigstr. 2
63755 Alzenau

Tel: +49 (0)180-5222580
Fax: +49 (0) 621-381-933129031
vertrieb.instrumentation@de.abb.com

USA

ABB Inc.
125 E. County Line Road
Warminster, PA
18974-4995

Tel: +1 (0)215 674 6000
Fax: +1 (0)215 674 7183
instrumentation@us.abb.com

Italy

ABB S.p.A.
Via Statale 113
22016 Lenno (CO)

Tel: +39 0344 58111
Fax: +39 0344 56278
abb.instrumentation@it.abb.com

UK

ABB Limited
Oldends Lane
Stonehouse
Gloucestershire GL10 3TA

Tel: +44 (0)1453 826 661
Fax: +44 (0)1453 829 671
instrumentation@gb.abb.com

P.R. China

ABB Engineering (Shanghai) Ltd.
32 Industrial Area
Kangqiao Town, Nanhui District
Shanghai, 201319

Tel: +86 (0) 21 6105 6666
Fax: +86 (0) 21 6105 6677
china.instrumentation@cn.abb.com