

TLP: CLEAR

REVISION: 2

PUBLICATION DATE: 2022-12-22

DOC. IDENTIFIER: 8DBD000083

PUBLISHER: HITACHI ENERGY PSIRT

DOCUMENT STATUS: FINAL

HITACHI
Inspire the Next

CYBERSECURITY ADVISORY

Multiple Vulnerabilities in Hitachi Energy's FOXMAN-UN Product

CVE-2021-40341

CVE-2021-40342

CVE-2022-3927

CVE-2022-3928

CVE-2022-3929

Notice

The information in this document is subject to change without notice and should not be construed as a commitment by Hitachi Energy. Hitachi Energy provides no warranty, express or implied, including warranties of merchantability and fitness for a particular purpose, for the information contained in this document, and assumes no responsibility for any errors that may appear in this document. In no event shall Hitachi Energy or any of its suppliers be liable for direct, indirect, special, incidental or consequential damages of any nature or kind arising from the use of this document, or from the use of any hardware or software described in this document, even if Hitachi Energy or its suppliers have been advised of the possibility of such damages. This document and parts hereof must not be reproduced or copied without written permission from Hitachi Energy and the contents hereof must not be imparted to a third party nor used for any unauthorized purpose. All rights to registrations and trademarks reside with their respective owners.

Summary

Hitachi Energy is aware of the use of Data Encryption Standard (DES) algorithm in the FOXMAN-UN and as well on multiple hardcoded credentials and non-secure communication used in the FOXMAN-UN. For details, please refer to the Vulnerability ID, Severity and Details section. An attacker that manages to exploit these vulnerabilities, may obtain sensitive information and gain access to the network elements that are managed by the FOXMAN-UN and could also cause availability issue on the FOXMAN-UN.

Please find remediation and mitigation information in the section Affected Products and Recommended Immediate Actions.

Vulnerability ID, Severity and Details

The vulnerability's severity assessment is performed by using the FIRST Common Vulnerability Scoring System (CVSS) v3.1. The CVSS Environmental Score, which can affect the final vulnerability severity score, is not provided in this advisory as it reflects the potential impact of the vulnerability in the customer organizations' computing environment. Customers are recommended to analyse the impact of the vulnerability in their environment and calculate the CVSS Environmental Score.

Vulnerability ID	Detail Description
<p>CVE-2021-40341 CVSS v3.1 Base Score: 7.1 High CVSS v3.1 Vector: AV:L/AC:L/PR:N/UI:N/S:C/C:H/I:N/A:N Link to NVD: click here CWE-326 – Weak encryption strength</p>	<p>FOXMAN-UN utilizes the DES cypher to encrypt user credentials used to access the Network Elements. DES is no longer considered secure because it uses a 56-bit key that is too short, allowing the cypher to be decrypted in a short time.</p>
<p>CVE-2021-40342 CVSS v3.1 Base Score: 7.1 High CVSS v3.1 Vector: AV:L/AC:L/PR:N/UI:N/S:C/C:H/I:N/A:N Link to NVD: click here CWE-1394 – Use of Default Cryptographic Key</p>	<p>FOXMAN-UN's DES implementation uses a default key for encryption. An attacker that manages to exploit this vulnerability will be able to obtain sensitive information and gain access to the network elements that are managed by the FOXMAN-UN.</p>
<p>CVE-2022-3927 CVSS v3.1 Base Score: 8.0 High CVSS v3.1 Vector: AV:N/AC:H/PR:H/UI:N/S:C/C:H/I:H/A:H Link to NVD: click here CWE-321 – Use of Hard-coded Cryptographic Key</p>	<p>Public and private key are found in FOXMAN-UN used to sign and protect Custom Parameter Set (CPS) file from modification. An attacker that manages to exploit this vulnerability will be able to change the CPS file, sign it so that it is trusted as the legitimate CPS file.</p>
<p>CVE-2022-3928 CVSS v3.1 Base Score: 7.1 High CVSS v3.1 Vector: AV:L/AC:L/PR:N/UI:N/S:C/C:H/I:N/A:N Link to NVD: click here CWE-321 – Use of Hard-coded Cryptographic Key</p>	<p>Hardcoded credential is found in FOXMAN-UN message queue. An attacker that manages to exploit this vulnerability will be able to access data to the internal message queue.</p>
<p>CVE-2022-3929 CVSS v3.1 Base Score: 8.3 High CVSS v3.1 Vector: AV:A/AC:H/PR:N/UI:N/S:C/C:H/I:H/A:H Link to NVD: click here CWE-319 – Cleartext Transmission of Sensitive Information</p>	<p>Communication between the client (FOXMAN-UN User Interface) and the server application (FOXMAN-UN Core) is partially using CORBA (Common Object Request Broker Architecture) over TCP/IP. This protocol is not encrypted and allows to trace internal messages.</p>

Affected Products and Recommended Immediate Actions

The Table below shows the affected version and the recommended immediate actions.

CVEs	Affected Version	Recommended Actions
CVE-2022-3928	FOXMAN-UN R15B	The vulnerabilities are remediated in FOXMAN-UN R16A.
CVE-2022-3929	FOXMAN-UN R15A*	Please upgrade to FOXMAN-UN R16A.
	FOXMAN-UN R14B*	For immediate recommended mitigation action if using FOXMAN-UN R15B and earlier, please refer to the following clause of section Mitigation Factors/Workarounds in this document: - Secure the NMS CLIENT/SERVER communication.
	FOXMAN-UN R14A*	
	FOXMAN-UN R11B*	
	FOXMAN-UN R11A*	
	FOXMAN-UN R10C*	
	FOXMAN-UN R9C*	
	Included all subversions*	
CVE-2022-3927	FOXMAN-UN R15B	The vulnerabilities are remediated in FOXMAN-UN R16A.
	FOXMAN-UN R15A*	Please upgrade to FOXMAN-UN R16A.
	FOXMAN-UN R14B*	For immediate recommended mitigation action if using FOXMAN-UN R15B and earlier, follow the recommended security practices as described in section Mitigation Factors/Workarounds in this document.
	FOXMAN-UN R14A*	
	FOXMAN-UN R11B*	
	FOXMAN-UN R11A*	
	FOXMAN-UN R10C*	
	FOXMAN-UN R9C*	
	Included all subversions*	
CVE-2021-40341	FOXMAN-UN R16A	The vulnerabilities are partially remediated in FOXMAN-UN R16A, the full remediation will be done in the upcoming FOXMAN-UN release (planned).
CVE-2021-40342	FOXMAN-UN R15B	
	FOXMAN-UN R15A*	For immediate recommended mitigation actions if using FOXMAN-UN R16A, please refer to the following clause of section Mitigation Factors/Workarounds in this document: - Database contains credentials with weak encryption.
	FOXMAN-UN R14B*	
	FOXMAN-UN R14A*	For immediate recommended mitigation actions if using FOXMAN-UN R15B and earlier, please refer to the following clause of section Mitigation Factors/Workarounds in this document: - Secure the NMS CLIENT/SERVER communication. - Embedded FOX CST with RADIUS authentication should be avoided. - Database contains credentials with weak encryption.
	FOXMAN-UN R11B*	
	FOXMAN-UN R11A*	
	FOXMAN-UN R10C*	
	FOXMAN-UN R9C*	
	Included all subversions*	

* No maintenance activity on this version.

Mitigation Factors/Workarounds

Recommended security practices and firewall configurations can help protect a process control network from attacks that originate from outside the network. Such practices include that process control systems are physically protected from direct access by unauthorized personnel, have no direct connections to the Internet, and are separated from other networks by means of a firewall system that has a minimal number of ports exposed, and others that have to be evaluated case by case. Process control systems should not be used for Internet surfing, instant messaging, or receiving e-mails. Portable computers and removable storage media should be carefully scanned for viruses before they are connected to a control system. Additionally, ensure that only authorized personnel(s) have access to the system configuration file.

Additional recommendation is to follow the hardening guidelines published by "The Center for Internet Security (CIS)" <https://www.cisecurity.org/about-us/> to protect the host Operating System.

Specific mitigation factors:

1. *Secure the NMS CLIENT/SERVER communication.* To secure the NMS Client/Server communication, follow the guideline "1KHW029191-FOXMAN-UN Client - Server Setup in a Secure Network".
2. *Embedded FOXCAST with RADIUS authentication should be avoided.* Problem exists only when remote authentication to Network Elements (NE) is used, alternatively from FOXMAN-UN R14A onwards it is possible to generate and exchange private/public keys, creating a trusted relation between FOXMAN-UN and FOX61x network elements.
3. *Database contains credentials with weak encryption.* It is important to ensure that the exported files shall be handled in secure way to ensure that only authorized persons can access them. To protect the database backup files, user access control or encrypting are possible solutions.

Frequently Asked Questions

What is FOXMAN-UN?

FOXMAN-UN is one of the elements in Hitachi Energy's comprehensive Network Management System (NMS) suite, is a powerful toolset providing all the essentials of a Network Management System, such as network status, alarm notification, and enhanced circuit provisioning functionality.

What might an attacker use the vulnerability to do?

An attacker who successfully exploited the vulnerability could take control of the Network Elements managed by the FOXMAN-UN system.

How could an attacker exploit the vulnerability?

An attacker could exploit the vulnerability by breaking the DES cipher using a brute force attack. This would require that the attacker has access to the system network, by connecting to the network either directly or through a wrongly configured or penetrated firewall, or that he installs malicious software on a system node or otherwise infects the network with malicious software. Recommended practices help mitigate such attacks, see section Mitigation Factors/Workarounds above.

Could the vulnerability be exploited remotely?

Yes, an attacker who has network access to an affected system node could exploit this vulnerability. Recommended practices include that process control systems are physically protected, have no direct connections to the Internet, and are separated from other networks by means of a firewall system that has a minimal number of ports exposed.

When this security advisory was issued, had this vulnerability been publicly disclosed?

No, this vulnerability has not yet been publicly disclosed before.

When this security advisory was issued, had Hitachi Energy received any report that this vulnerability was being exploited?

No, Hitachi Energy had not received any information indicating that this vulnerability had been exploited when this security advisory was originally issued.

Acknowledgement

Hitachi Energy thanks the following for working with us to help protect customers:
K-Businessom AG, Austria

Support

This advisory will be updated as new relevant information becomes available. Please subscribe to Hitachi Energy's Cybersecurity Alerts & Notifications to get notified:

<https://www.hitachienergy.com/offering/solutions/cybersecurity/alerts-and-notifications/subscribe>

For additional information and support please contact your product provider or Hitachi Energy service organization. For contact information, see <https://www.hitachienergy.com/contact-us/> for Hitachi Energy contact-centers.

Publisher

Hitachi Energy PSIRT – cybersecurity@hitachienergy.com

Revision

Date of the Revision	Revision	Description
2022-12-13	1	Initial public release.
2022-12-22	2	Added acknowledgement to K-Businesscom AG, Austria

DS

