



Ref. Certif. No.

**SE-93026**

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**

**CB TEST CERTIFICATE**

Product	Control circuit device and switching element
Name and address of the applicant	ABB France 3 Rue Jean Perrin, CS 90009 69687 Chassieu Cedex, FRANCE
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Fideltronik Poland Sp. z o.o. ul. Beniowskiego 1 34-200 SUCHA BESKIDZKA, POLAND
Ratings and principal characteristics	AC15: 250V/0,75A, 120V/1,5A (C300) AC15: 250V/1,5A
Trademark (if any)	<b>ABB</b>
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	RA4
Additional information (if necessary may also be reported on page 2)	See page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-5-1:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	1818574STO-001


This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Box 1103  
SE-164 22 Kista, Sweden  
Int +46 8 750 00 00

Date: 15 January 2019

**intertek**

Signature:

  
Henrik Wikström



Ref. Certif. No.

**SE-93026**

**Additional information (if necessary)**

Rated insulation voltage,  $U_i = 250V$ .  
Rated impulse withstand voltage,  $U_{imp} = 4kV$ .  
Rated conditional short-circuit current 100A.

This certificate replaces CB certificate SE-81055, dated 10 December 2015. A new certificate is issued due to changed type designation and new edition of the standard.

Date: 15 January 2019

Signature:

