



Test Report				Date of issue: 5.6.2014							
				Serial No.: 3GP11020934							
				Type: M3KP 315SMC 6 B3							
				Product Code: 3GKP313230-ADG							
				Protection type: Ex de IIB T4 Gb							
				Cert. No.: LCIE 11 ATEX 3090X / IECEx LCI 04.0007X							
Rating:				V	Hz	kW	r/min	A	cos φ	Duty	
3-Motor				400	D 50	110	991	201	0,83	S1	
Insul.cl.F				415	D 50	110	992	196	0,82	S1	
IP55				690	Y 50	110	991	117	0,83	S1	
Eff class IE2				400 V 50Hz : IE2 - 95.0(100%) - 95.0(75%) - 94,6(50%)							
Resistance Line				Ambient: 20,0 °C				Insulation resistance at 47,5 °C		Overload	
U ₁ - V ₁				0,02490 Ω				14000 MΩ		1000 V	
U ₁ - W ₁				0,02488 Ω						Torque 160 % 15s	
V ₁ - W ₁				0,02491 Ω							
								High-voltage test winding		1900 V 60 s	
Test	Torque [Nm]	Line U[V]	f[Hz]	Input I[A]	P1 [kW]	Output P2 [kW]	n[r/min]	cos φ	η [%]		
No load test		399,9 D	50	74,8	2,30		1000	0,04			
Locked rotor test		76,8 D	50	202,0	8,16		0	0,30			
Thermal test (100% load)	1060,0	400,3 D	50	202,1	116,1	110,0	992	0,83	94,8		
Partial load points:											
~75% load	795,7	400,1 D	50	158,6	86,9	82,5	994	0,79	95,0		
~50% load	529,0	400,2 D	50	119,7	58,2	55,0	996	0,70	94,5		
~25% load	264,0	400,1 D	50	88,9	30,1	27,5	998	0,49	91,5		
Temperature rise at rated load.				[°C]	[K]	Method		Measurement method			
Stator winding :				57,7	1	1		Resistance			
Frame :				33,5	2	2		Thermometer			
Bearing D-end :				48,3	2	2		Thermocouples			
Ambient Temperature :				25,0	2						
Manufactured and tested in accordance with rules of IEC 60034-1 and IEC 60034-2-1. PLL determined from residual loss.											
On behalf of customer											
On behalf of manufacturer				Date of test		26.10.2011					
Tested by ABB Oy, Motors and Generators, Vaasa, Finland								Telephone		+358 10 2211	
								Telefax		+358 10 22 47372	

Computer print-out valid without signature.

ABB, Motors and Generators
www.abb.com/motors&generators