

产品认证证书

II型自愿认证

证书编号: CQC2011010304514755

发证日期: 2021年09月10日

有效期至: 2031年09月10日

委托人名称 ABB Electrification Sweden AB, Motor Starting & Safety
及注册地址 Motorgrand 20, 72161 Vasteras, Sweden

制造商名称 ABB Electrification Sweden AB, Motor Starting & Safety
及注册地址 Motorgrand 20, 72161 Vasteras, Sweden

生产企业名称 ABB 新会低压开关有限公司
及生产地址 广东省江门市新会区今古洲工业开发区

产品名称和系列、规格、型号 接触器
AF400-30-□□, AF460-30-□□; 规格参数详见附件

产品标准和技术要求 GB/T 14048.4-2020


认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年08月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

刘江

谢肇煦



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0104113

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2011010304514755

Valid from: Sep.10,2021

Valid until: Sep.10,2031

NAME AND REGISTERED
ADDRESS OF THE APPLICANT

ABB Electrification Sweden AB, Motor Starting & Safety
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER

ABB Electrification Sweden AB, Motor Starting & Safety
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND LOCATION
OF THE FACTORY

ABB Xinhui Low Voltage Switchgear Co., Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province,
P.R.China

PRODUCT NAME, MODEL
AND SPECIFICATION

Contactor
AF400-30-□□, AF460-30-□□; See the Appendix

THE STANDARDS AND
TECHNICAL REQUIREMENTS
FOR THE PRODUCTS

GB/T 14048.4-2020

TYPE OF CERTIFICATION
SCHEMES


Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Aug.14,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

刘江

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0104113

产品认证证书

II型自愿认证

证书编号: CQC2011010304514755

第 1 页 共 2 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 104113

上报参数:

AF400-30-*, AF460-30-*

Ui:1000V;

Uimp:8kV;

AF400-30-*:

Ith:600A;

AC-3:Ue/Ie: 220-240V/380-400V/415V/440V/400A;

660-690V/350A, 1000V/155A;

AC-1:Ue/Ie:415V/690V/600A;

AF460-30-*:

Ith:700A;

AC-3:Ue/Ie: 220-240V/380-400V/415V/440V/460A;

660-690V/400A, 1000V/200A;

AC-1:Ue/Ie:415V/690V/700A;

极数: 3P;

Us: 24-60V d.c., 48-130V 50/60Hz, d.c., 100-250V 50/60Hz,d.c.,

250-500V 50/60Hz, d.c;

配用辅助触头: (外置)

CAL18: CQC2009010304365509;

Ith: 16A;

AC-15: Ue/Ie:127V/6A, 230/240V/4A,400/440V/3A, 500/690V/2A;

DC-13: Ue/Ie:24V/6A, 48V/2.8A, 72V/1A, 125V/0.55A, 250V/0.3A;

1NO1NC,2NO2NC



中国质量认证中心



产品认证证书

II型自愿认证

证书编号: CQC2011010304514755

第 2 页 共 2 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 104113

型号解释:

AF460 -3 0- *

附件种类数量: 空白或 00: 没有附加附件; 11: 附加一只 CAL18 系列附件; 22: 附加两只 CAL18 系列附件

常闭主触点对数 0: 0 对常闭主触点

常开主触点对数 3: 3 对常开主触点

额定电流规格 400, 460; 额定工作电压 380V
AC-3 下额定工作电流 400A 或 460A

系列名称: AF 系列接触器



中国质量认证中心

