



Test Report				Date of issue: 4.6.2014						
				Serial No.: 3GF11094409						
				Type: M3JP 400LC 8						
				Product Code: 3GJP404530-_DG						
				Protection type: Ex d IIB T4 Gb						
				Cert. No.: LCIE 10 ATEX 3004X / IECEx LCI 04.0032X						
Rating:										
	V	Hz	kW	r/min	A	cos φ				
3~Motor	690	Y 50	400	744	424	0,82				
Insul.cl.F	400	D 50	400	744	731,0	0,82				
S1 AMB -20...+40°C	660	Y 50	400	743	438	0,83				
IP55	380	D 50	400	743	761	0,83				
3680 kg	415	D 500	400	744	722	0,8				
	440	D 60	450,0	893	740,0	0,83				
Resistance			Ambient: 27,5 °C			Insulation resistance at 83,0 °C		Overload test 1,6x T _N 15s		
Line			0,00430 Ω			7000 MΩ		1000 V		
U ₁ - V ₁			0,00430 Ω					Starting Current I _S /I _N = 6,02		
U ₁ - W ₁			0,00430 Ω							
V ₁ - W ₁			0,00430 Ω							
					High-voltage test winding		1900 V		60s	
Test	Torque [Nm]	Line U[V]	f[Hz]	Input I[A]	P1 [kW]	Output P2 [kW]	η[r/min]	cos φ	η [%]	
No load test		400,0 D	50	259,0	5,07			0,03		
Locked rotor test		87,2 D	50	731,2	21,53			0,19		
Temperature-rise test		400,8 D	50	735,3	416,4	400,0	744	0,82	96,1	
Temperature rise at rated load.		[°C]		[K]	Method		Measurement method			
Stator winding :				68,9	1		1 Resistance			
Frame :				44,5	3		2 Thermometer			
Bearing D-end :				49,0	3		3 Thermocouples			
Rotor:				120,9	2					
Ambient Temperature :		25,0								
<p>These tests have been carried out on motor no. 3GF11069476C, on date 2011-06-10, which is identical in design with the above.</p>										
<p>Manufactured and tested in accordance with rules of IEC 60034-1 and IEC 60034-2-1. PLL determined from residual loss.</p>										
On behalf of customer										
On behalf of manufacturer										
Tested by ABB Oy, Motors and Generators, Vaasa, Finland					Telephone +358 10 2211 Telefax +358 10 22 47372					

Computer print-out valid without signature.

ABB, Motors and Generators
www.abb.com/motors&generators