

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit breaker

Name and address of the applicant

ABB Switzerland Ltd Low Voltage Products
Fulachstrasse 150, 8201 SCHAFFHAUSEN
SWITZERLAND

Name and address of the manufacturer

ABB Switzerland Ltd Low Voltage Products
Fulachstrasse 150, 8201 SCHAFFHAUSEN
SWITZERLAND

Name and address of the factory

ABB Switzerland Ltd Low Voltage Products
Fulachstrasse 150, 8201 SCHAFFHAUSEN
SWITZERLAND

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

230/400 V a.c.; In = 32 ... 125 A; Characteristic B; C; D; K; Icu = 16 kA; Ics = 10 kA

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Series S800B

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007
IEC 60947-1:2007/AMD1:2010
IEC 60947-1:2007/AMD2:2014
IEC 60947-2:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

252694-TL3-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2019-02-15

Signature:

J. Richter