


CENELEC CERTIFICATION AGREEMENT

ACCORD DE CERTIFICATION DU CENELEC
CENELEC-ZERTIFIZIERUNGS-ABKOMMEN



NOTIFICATION OF TEST RESULTS

NTR/31071/IMQ

<i>Product</i>	Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)
<i>Tested by request of</i>	ABB S.p.A. Via Vittor Pisani 16 20124 Milano (MI) – Italy
<i>Manufactured at (name and place)</i>	ABB S.p.A. Via Ardeatina 2491 00040 Santa Palomba (RM) – Italy
<i>Preliminary visit carried out by</i>	IMQ
<i>Rating and principal characteristics</i>	1P+N – Un = 230 V – Curve C – In = 6, 10, 16, 20, 25 or 32 A type AC, A or APR – IΔn = 10, 30 or 300 mA Icn = 4500 A – IΔm = 4500 A (see pages 4, 6 and 7 of Test Report PB18-0031588-01-00)
<i>Trade mark (if any)</i>	
<i>Model/Type Ref.</i>	Series DS201 L (see pages 6 and 7 of Test Report PB18-0031588-01-00)
<i>Additional information (if necessary)</i>	THIS PRODUCT IS COVERED BY A LICENCE OF IMQ MARK IMQ APPROVAL CERTIFICATE No. CA03.00831 Testing location/procedure: CTF Stage 2
<i>A sample of the product has been tested and found to be in conformity with (HD/EN and equivalent national standard)</i>	
<ul style="list-style-type: none">• EN 61009-1:2012 + A1:2014 + A2:2014 + A11:2015 + A12:2016• EN 61009-2-1:1994 + A11:1998	
<i>as shown in the test reports (reference No.)</i>	PB18-0031588-01-00 and from PB18-0031588-01-01 to PB18-0031588-01-15

This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This Notification of Test Results has been established by a body which participates directly in the CENELEC Certification Agreement (CCA) of September 11th, 1973 as revised on March 29th, 1983 and September 3rd, 2004 (including addendum 1 dated July 1984, addendum 2 dated March 1987, addendum 3 dated September 1989 and addendum 4 dated March 1995). Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA.

IMQ S.p.A.

Milano, 2019-01-24

Signature of the authorized person _____

Name and function of the authorized person

Mauro Casari

**B.U. "Product Conformity Assessment"
"Project Management & Certification" Area
"Certification" Sector (voluntary field) - Manager**

Tel.: (+39) 02-50731

Fax.: (+39) 02-50991500

e-mail: info@imq.it