

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Switch-disconnector

Name and address of the applicant

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the factory

ABB Bulgaria EOOD - Rakovski Branch -  
Rakovski Industrial zone 14, Industrial Road 1, 4142  
RAKOVSKI  
BULGARIA*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

 Additional Information on page 2Ie = 16 / 25 / 32 / 40 / 50 / 63 A;  
AC-22A: 240 V a.c., 1-pole; AC-22A: 415 V a.c., 2-, 3-, 4-pole;  
Rated conditional short-circuit current 5 kA

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Series BMD51

Additional information (if necessary may also be reported on page 2)

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020  
IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

276435-TL3-1

This CB Test Certificate is issued by the National Certification Body

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierungsstelle und internat. Angelegenheiten  
Certification Body and internat. Affairs

Date: 2020-11-30

Signature:

  
R. Nickel