


ABB Drives

User's Manual Digital I/O Extension FIO-31



Digital I/O Extension
FIO-31

User's Manual

3AUA0000055162 Rev A
EN
EFFECTIVE: 01.04.2009

Safety instructions

Overview

This chapter states the general safety instructions that must be followed when installing and operating the FIO-31 Digital I/O Extension.

In addition to the safety instructions given below, read the complete safety instructions of the specific drive you are working on.

These warnings are intended for all who work on the drive. Ignoring the instructions can cause physical injury or death, or damage the equipment.

General safety instructions



WARNING! All electrical installation and maintenance work on the drive should be carried out by qualified electricians only.

The drive and adjoining equipment must be properly earthed.

Do not attempt any work on a powered drive. After switching off the mains, always allow the intermediate circuit capacitors to discharge for 5 minutes before working on the frequency converter, the motor or the motor cable. It is good practice to check (with a voltage indicating instrument) that the drive is in fact discharged before beginning work.

The motor cable terminals of the drive are at a dangerously high voltage when mains power is applied, regardless of motor operation.

There can be dangerous voltages inside the drive from external control circuits even when the drive mains power is shut off. Exercise appropriate care when working on the unit.

Table of contents

Safety instructions	5
Overview	5
General safety instructions	5
 Table of contents	 7
 Introduction	 9
Intended audience	9
Before you start	9
What this manual contains	9
Product and service inquiries	10
Product training	10
Providing feedback on ABB Drives manuals	10
 Overview	 11
Overview	11
The FIO-31 Digital I/O Extension	11
 Installation	 13
Mounting	13
Terminal designations	14
Wiring	15
Programming	15
 Fault tracing	 17
Diagnostic LEDs	17
 Technical data	 19

Introduction

Intended audience

The manual is intended for the people who are responsible for commissioning and using the FIO-31 Digital I/O Extension. The reader is expected to have a basic knowledge of electrical fundamentals, electrical wiring practices and how to operate the drive.

Before you start

It is assumed that the drive is installed and the drive power supply is switched off before starting the installation of the extension module. Ensure that all dangerous voltages connected from external control circuits to the inputs and outputs of the drive are switched off.

In addition to conventional installation tools, have the drive manuals available during the installation as they contain important information not included in this manual. The drive manuals are referred to at various points of this document.

What this manual contains

This manual contains information on the wiring, configuration and use of the FIO-31 Digital I/O Extension.

Safety instructions are featured in the first few pages of this manual.

Overview contains a short description of the FIO-31.

Installation contains instructions for hardware settings, mounting and cabling.

Fault tracing explains LED indications.

Technical data contains detailed technical information.

Product and service inquiries

Address any inquiries about the product to your local ABB representative, quoting the type code and serial number of the unit in question. A listing of ABB sales, support and service contacts can be found by navigating to www.abb.com/drives and selecting *Sales, Support and Service network*.

Product training

For information on ABB product training, navigate to www.abb.com/drives and select *Training courses*.

Providing feedback on ABB Drives manuals

Your comments on our manuals are welcome. Go to www.abb.com/drives and select *Document Library – Manuals feedback form (LV AC drives)*.


Overview

Overview

This chapter contains a short description of the FIO-31 Digital I/O Extension.

The FIO-31 Digital I/O Extension


The FIO-31 is a general purpose relay extension. It offers four relay outputs.



FIO-31 layout

Isolation areas

The following figure describes the different isolation areas of the module.



The fixing screw connects the chassis to ground.

Installation



WARNING! Follow the safety instructions given in this manual and in the drive *Hardware Manual*.

Mounting



WARNING! Before installation, switch off the drive power supply. Wait for five minutes to ensure that the capacitor bank of the drive is discharged. Switch off all dangerous voltages connected from external control circuits to the inputs and outputs of the drive.

The FIO-31 is to be inserted into the option slot of the drive. The module is held in place with plastic retaining clips and one screw. On installation of the module, the signal and power connection to the drive is automatically made through a 20-pin connector.

Mounting procedure:

- Insert the module carefully into the option slot until the retaining clips lock the module into position.
 - Fasten the screw (included) to the stand-off.
-

Note: Correct installation of the screw is essential for fulfilling the EMC requirements and for proper operation of the module.

Installation sites above 2000 metres (6562 feet)

The Protective Extra Low Voltage (PELV) requirements are not fulfilled when altitude is greater than 2000 m (6562 feet) and relays are used with voltage greater than 48 V.

Terminal designations

Marking		Description
X101		Relay output • 240 V AC / 30 V DC, 2 A • NO = relay normally open • COM = common • NC = relay normally closed
1	RO1NO	
2	RO1COM	
3	RO1NC	
X102		
1	RO2NO	
2	RO2COM	
3	RO2NC	
X103		
1	RO3NO	
2	RO3COM	
3	RO3NC	
X104		
1	RO4NO	
2	RO4COM	
3	RO4NC	

Wiring

Maximum 2.5 mm² (AWG 14) cable should be used for the signals. The cable shields should be connected to the JCU Control Unit. See the drive *Hardware Manual* for more information.

Note: Do not route signal cables parallel to power (e.g. motor) cables.

Tightening torque is 0.5 N·m (4.4 lb·in) for the plugs.

Programming

The communication between the module and the drive is activated by a drive parameter. See the drive *Firmware Manual*.


Fault tracing

Diagnostic LEDs

	Colour	Description
STATUS LED	Green	OK
	Red	Power fault & not initialized or communication fault to control unit

Technical data

Dimensions



General

- Max. power consumption: 60 mA at 24 V, 250 mA at 3.3 V
- Degree of protection: IP20
- Ambient conditions: The applicable ambient conditions specified for the drive in its *Hardware Manual* are in effect.

Connectors

- 20 pin socket
- 4 pcs. 3-pole detachable terminal plugs.

Relay output

- 240 V AC or 30 V DC, 2 A resistive load
- Varistors for inductive load protection.



ABB Oy

AC Drives

P.O. Box 184

FIN-00381 HELSINKI

FINLAND

Telephone +358 10 22 11

Telefax +358 10 22 22681

Internet www.abb.com**ABB Inc.**

Automation Technologies

Drives & Motors

16250 West Glendale Drive

New Berlin, WI 53151

USA

Telephone 262 785-3200

800-HELP-365

Telefax 262 780-5135

**ABB Beijing Drive Systems
Co. Ltd.**

No. 1, Block D,

A-10 Jiuxianqiao Beilu

Chaoyang District

Beijing, P.R. China, 100015

Telephone +86 10 5821 7788

Fax +86 10 5821 7618

3AUA0000055162 Rev A / EN
EFFECTIVE: 01.04.2009