

CERTIFICATE OF COMPLIANCE

Certificate Number E495921
Report Reference E495921-20180208
Issue Date 2020-APRIL-02

Issued to: ABB Oy, Smart Power
MUOTTITIE 2 A
PO BOX 622
FI-65101 VAASA FINLAND

**This certificate confirms that
representative samples of**

**AUTOMATIC TRANSFER SWITCHES FOR USE IN
EMERGENCY SYSTEMS**

Automatic Transfer Switches, open type, Cat Nos. OX followed by A, followed by 400 or 600, followed by U, followed by 2 or 3, followed by S, O, N or X, followed by 2, 3 or 4, followed by Q, followed by B or T may be followed by -ZE.

Cat Nos. OX followed by A, followed by 260, followed by U, followed by 2 or 3, followed by S, O, N or X, followed by 2, 3 or 4, followed by Q, followed by B or T, followed by +, may be followed by -ZE.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1008 and CSA C22.2 NO. 178.1-14 - TRANSFER SWITCH EQUIPMENT.

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

