

产品认证证书

II型自愿认证

证书编号: CQC23107409295

发证日期: 2023年10月26日

有效期至: 2033年10月25日

委托人名称 及注册地址 ABB Switzerland Ltd, Low Voltage Products
Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland

制造商名称 及注册地址 ABB Switzerland Ltd, Low Voltage Products
Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland

生产企业名称 及生产地址 ABB Switzerland Ltd, Low Voltage Products
Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland

产品名称和系列、规格、型号 塑料外壳式断路器
S801P, S802P, S803P, S804P Ui:690V;Uimp:6kV;Ue: AC240V(1P),
AC240/415V(2P,3P,4P);In: 63A,80A,100A,125A;过电流脱扣器类型: 热磁式;Ics: 40kA;Icu:
50kA;选择性类别: A;极数: 1P,2P,3P,4P;适用于隔离;适用频率:50/60Hz。

产品标准和技术要求 GB/T 14048.2-2020

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



授权签字人

签发

郑泉

谢肇煦



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0258897

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC23107409295

Valid from: Oct.26,2023

Valid until: Oct.25,2033

NAME AND REGISTERED ADDRESS OF THE APPLICANT	ABB Switzerland Ltd, Low Voltage Products Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	ABB Switzerland Ltd, Low Voltage Products Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland
NAME AND LOCATION OF THE FACTORY	ABB Switzerland Ltd, Low Voltage Products Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland
PRODUCT NAME, MODEL AND SPECIFICATION	Moulded Case Circuit-breaker S801P, S802P, S803P, S804P Ui:690V;Uimp:6kV;Ue: AC240V(1P) , AC240/415V(2P,3P,4P);In: 63A,80A,100A,125A;Over-current ReleaseType: TMU;ics: 40kA;Icu: 50kA;Selectivity category: A;Poles: 1P,2P,3P,4P;Suitable for isolation;50/60Hz.
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.2-2020
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

郑+泉

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE

