

IEC**IECEE**

®

TM

Ref. Certif. No.

CN47125-A2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Mini Contactor

Name and address of the applicant

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

Name and address of the manufacturer

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

Name and address of the factory

ABB Industrial Solutions (Kłodzko) Sp. z o.o.
ul. Pilsudskiego 5, 57-300 Kłodzko, Poland

Note: When more than one factory, please report on page 2

 Additional information on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

ABB

Customer's Testing Facility (CTF) Stage used

MC1, MC2, MC1...-RAIL, MC2...-RAIL;

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

IEC 60947-4-1:2009(3rd Edition) + AMD 1:2012

A sample of the product was tested and found to be in conformity with

00901-CB2019CQC-085551-A2

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Mar.25,2021

Signature:

Lu Mei

CB 0061172

MC1, MC2, MC1...-RAIL, MC2...-RAIL

Uimp: 6kV;

Ui: 750V;

Ith: 20A;

MC1, MC1...-RAIL:

AC-1:Ue/Ie:690V/20A;

AC-3:Ue/Ie:400V/9A,500V/8A,690V/6A;

AC-4:Ue/Ie:400V/9A,500V/8A,690V/6A;

MC2, MC2...-RAIL:

AC-1:Ue/Ie:690V/20A;

AC-3:Ue/Ie:400V/12A,500V/10A,690V/8A;

AC-4:Ue/Ie:400V/9A,500V/8A,690V/6A;

Us:24V,48V,120V,220-230V,240V 50/60Hz,115-127V 50Hz,208-220V 60Hz,

110-115V 50Hz/110-120V 60Hz,220-240V 50Hz/277V 60Hz,380-400V 50Hz/440V 60Hz

415-440V 50Hz/480V 60Hz,500V 50Hz/600V 60Hz,

24V,48V,110V,125V,220V,12V,33V,72V DC;

3P,4P;

IP20;

Auxiliary contact:(body contact)

1NO,1NC;

Ith:16A;

AC-15:Ue/Ie:120V/6A, 240V/6A, 400V/4A, 500V/2.5A, 690V/1.5A;

DC-13:Ue/Ie:24V/5A, 48V/3.5A, 125V/1.2A, 250V/0.6A, 440V/0.25A

Page 1 of 1

Additional information (if necessary)

Date:

Mar.25,2021

Signature:



Lu Mei

IEC**IECEE**

®

TM

Ref. Certif. No.

CN47125-A2

| Name of the factory | Address of the factory |
|---------------------------------------|--|
| 1.ABB Bulgaria EOOD – Rakovski branch | BULGARIA, 4142 Village of Stryama, Region of Plovdiv, Municipality of Rakovski, Rakovski Industrial Zone, 14 Industrial Road 1, nr,14-18 |

Additional information (if necessary)

Date: Mar.25,2021

Signature:



Lu Mei