



# 中国国家强制性产品认证证书

证书编号: 2024010304658955

认证委托人名称及地址

ABB AG  
Kallstadter Str. 1 68309 Mannheim Germany

生产者名称及地址

ABB AG - STOTZ-KONTAKT  
Eppelheimer Str. 82 DE-69123 Heidelberg

生产企业名称及地址

ABB AG - STOTZ-KONTAKT  
Eppelheimer Str. 82 DE-69123 Heidelberg

产品名称和系列、型号、规格

家用及类似用途机电式接触器

ESB40-xxN, ESB63-xxN, EN40-xxN; Ui: 500V; Ith: 63A( ESB63-xxN), 40A(ESB40-xxN, EN40-xxN); ESB40-xxN, EN40-xxN: AC-7a: Ue/Ie: AC400V/40A(NO), AC400V/30A(NC); ESB63-xxN : AC-7a: Ue/Ie: AC400V/63A(NO), AC400V/30A(NC); ESB40-xxN, EN40-xxN: AC-7b: Ue/Ie: AC400V/22A(NO); ESB63-xxN : AC-7b: Ue/Ie: AC400V/30A(NO); Us: 12V, 24V, 42V, 48V, 110V, 230V, 240V, 400V, 415V 50/60Hz/DC; DC24V; IP20; 极数: 4P; 型号解释详见附页

产品标准和技术要求

GB/T 17885-2016

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》(CNCA-C03-02:2024)的要求,特发此证。

发证日期: 2026年05月15日 有效期至: 2029年07月16日

本证书为变更证书,证书首次颁发日期: 2024年07月17日  
证书信息和有效性可扫描下方二维码或登录发证机构网站查验,  
也可在认监委网站([www.cnca.gov.cn](http://www.cnca.gov.cn))查询。



签发:

刘江



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





# 中国国家强制性产品认证证书

证书编号：2024010304658955

证书附页：第 1 页 共 2 页

型号解释：

<u>ESB</u>	<u>40</u>	-	<u>22</u>	N	-	<u>xx</u>
1	2		3	4		5

## 1. Model name

ESB - standard model

EN - with additional manual operation

## 2. Basic type 40

## 3. Contact variants of the contactor

40 4 NO

22 2 NO / 2 NC

20 2 NO

30 3 NO

31 3 NO / 1 NC

11 1 NO / 1 NC

02 2 NC

## 4. ESB series suffix

N - upgraded version

## 5. optional for marketing or customer, letter, number and symbol, DC-B

本页为证书附页，应与证书主页同时使用。



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



# 中国国家强制性产品认证证书

证书编号：2024010304658955

证书附页：第 2 页 共 2 页

Type	Contacts	Remarks
EN40-40N/EN40-40	4 NO	
EN40-20N	2 NO	
EN40-30N	3 NO	
EN40-31N	3 NO + 1NC	
ESB40-40N	4 NO	
ESB40-22N	2 NO + 2 NC	
ESB40-20N	2 NO	
ESB40-30N	3 NO	
ESB40-31N	3 NO + 1NC	
ESB63-40N	4 NO	
ESB63-22N	2 NO + 2 NC	
ESB63-20N	2 NO	
ESB63-30N	3 NO	
ESB63-31N	3 NO + 1NC	
ESB63-11N	1 NO + 1 NC	

本页为证书附页，应与证书主页同时使用。



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

**CERTIFICATE NO.:** 2024010304658955

**NAME AND ADDRESS OF THE APPLICANT**

ABB AG  
Kallstadter Str. 1 68309 Mannheim Germany

**NAME AND ADDRESS OF THE MANUFACTURER**

ABB AG – STOTZ-KONTAKT  
Eppelheimer Str. 82 DE-69123 Heidelberg

**NAME AND LOCATION OF THE FACTORY**

ABB AG – STOTZ-KONTAKT  
Eppelheimer Str. 82 DE-69123 Heidelberg

**PRODUCT NAME,MODEL AND SPECIFICATION**

Electromechanical contactors for household and similar purposes

ESB40-xxN, ESB63-xxN, EN40-xxN; Ui: 500V;Ith: 63A( ESB63-xxN), 40A(ESB40-xxN , EN40-xxN); ESB40-xxN, EN40-xxN: AC-7a: Ue/Ie: AC400V/40A(NO), AC400V/30A(NC);ESB63-xxN : AC-7a: Ue/Ie: AC400V/63A(NO), AC400V/30A(NC);ESB40-xxN, EN40-xxN: AC-7b: Ue/Ie: AC400V/22A(NO);ESB63-xxN : AC-7b: Ue/Ie: AC400V/30A(NO); Us: 12V, 24V, 42V, 48V, 110V, 230V, 240V, 400V, 415V 50/60Hz/DC; DC24V;IP20;Poles: 4P;

**STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T 17885-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

**Valid from:** May.15,2026

**Valid until:** Jul.16,2029

Date of original issued: Jul.17,2024

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

CERTIFICATE NO. : 2024010304658955

Appendix: Page 1 of 1

ESB      40 - 22    N   - xx  
1            2        3    4        5

1. Model name

ESB - standard model

EN - with additional manual operation

2. Basic type 40

3. Contact variants of the contactor

40    4 NO

22    2 NO / 2 NC

20    2 NO

30    3 NO

31    3 NO / 1 NC

11    1 NO / 1 NC

02    2 NC

4. ESB series suffix

N - upgraded version

5. optional for marketing or customer, letter, number and symbol, DC-B

Type	Contacts	Remarks
EN40-40N/EN40-40	4 NO	
EN40-20N	2 NO	
EN40-30N	3 NO	
EN40-31N	3 NO + 1NC	
ESB40-40N	4 NO	
ESB40-22N	2 NO + 2 NC	
ESB40-20N	2 NO	
ESB40-30N	3 NO	
ESB40-31N	3 NO + 1NC	
ESB63-40N	4 NO	
ESB63-22N	2 NO + 2 NC	
ESB63-20N	2 NO	
ESB63-30N	3 NO	
ESB63-31N	3 NO + 1NC	
ESB63-11N	1 NO + 1 NC	

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.