



Ref. Certif. No.

CN28664-A2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

## CB TEST CERTIFICATE

Product  
Produit

Contactor relay

Name and address of the applicant  
Nom et adresse du demandeurABB France  
3 Rue Jean Perrin CS 90009 69687,Chassieu Cedex,FRANCEName and address of the manufacturer  
Nom et adresse du fabricantABB France  
3 Rue Jean Perrin CS 90009 69687,Chassieu Cedex,FRANCEName and address of the factory  
Nome et adresse de l'usineNote: When more than one factory, please report on page 2  
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2<sup>ème</sup> pageABB Xinhui Low Voltage Switchgear Co., Ltd  
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City,  
Guangdong ProvinceRatings and principal characteristics  
Valeurs nominales et caractéristiques principalesUi:690V;Ith:16A; AC-15:Ue/Ie:24~127V/6A,230~240V/4A, 400~415  
V/3A,500~690V/2A; DC-13:Ue/Ie:24V/6A,48V/2.8A,72V/1A,125V/0.55  
A, 250V/0.3A; Us:220-230V 50Hz/230-240 60Hz,24V 50/60Hz, 48V 5  
0/60Hz,110V 50Hz/110-120V 60Hz, 380-400V 50Hz/400-415V 60Hz, 4  
00-415V 50Hz/415-440V 60Hz, 230-240V 50Hz/240-260V 60Hz, 190V  
50Hz/220V 60Hz;105V 50Hz/110-127V 60Hz;200V 50Hz/200-220V 60  
Hz; IP20 (Applies only to the front)Trademark (if any)  
Marque de fabrique (si elle existe)

ABB

Model / Type Ref.  
Ref. De type

NX

Additional information (if necessary may also be reported  
on page 2)  
Les informations complémentaires (si nécessaire, peuvent être  
indiqués sur la 2<sup>ème</sup> page)The latest CB is CN28664-A1, dated 2014-11-20. The A2 certificate has  
been issued to add another factory **PUBLICATION EDITION**A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 60947-5-1:2003(3rd edition)+A1:2009

As shown in the Test Report Ref. No. which forms part  
of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

00901-CB2013CQC-053572-M1-A1

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

CHINA QUALITY CERTIFICATION CENTRE

Date: 2017-03-22

Signature: Wang Kejiao

IEC

IECEE  
CB  
SCHEME

Ref. Certif. No.

CN28664-A2

1.ABB SA

RUTA NACIONAL 157 KM 1233 5 BELLA VISTA  
POST 4168 TUCUMAN ARGENTINA

2.ABB Bulgaria EOOD - Rakovski branch

Industrial Zone, Plovdiv District, Rakovski  
Municipality, 4150 RAKOVSKI BULGARIA

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2017-03-22

Signature:



Wang Kejiao