


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Circuit breaker
Name and address of the applicant	ABB-Stotz-Kontakt GmbH Eppelheimer Straße 82, 69123 Heidelberg GERMANY
Name and address of the manufacturer	ABB-Stotz-Kontakt GmbH Eppelheimer Straße 82, 69123 Heidelberg GERMANY
Name and address of the factory	ABB s.r.o. Herspicka 13, 619 00 Brno CZECH REPUBLIC
<i>Note: When more than one factory, please report on page 2</i>	<input checked="" type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	AC 230/400 V; In = 16 A, 20 A, 25 A, 32 A, 40 A, 50 A, 63 A, 80 A, 100 A; Characteristic E, K; Icu = 25 kA; Ics = 12,5 kA
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	CTF Stage 2
Model / Type Ref.	Series S750 DR
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2007 IEC 60947-1:2007/AMD1:2010 IEC 60947-1:2007/AMD2:2014 IEC 60947-2:2016 IEC 60947-2:2016/AMD1:2019
As shown in the Test Report Ref. No. which forms part of this Certificate	275459-TL3-1

This CB Test Certificate is issued by the National Certification Body

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierungsstelle und internat. Angelegenheiten  
Certification Body and internat. Affairs

Date: 2020-10-29

Signature:

  
R. Nickel



Ref. Certif. No.

**DE1-64104**

ABB Bulgaria EOOD - Rakovski Branch -  
- Rakovski Branch -, Rakovski Industrial zone,, 14,  
Industrial Road 1, 4142 RAKOVSKI  
BULGARIA

**Additional information (if necessary)**

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierungsstelle und internat. Angelegenheiten  
Certification Body and internat. Affairs

Date: 2020-10-29

Signature:

  
R. Nickel