



中国国家强制性产品认证证书

证书编号: 2004010304138321

委托人名称、地址

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

生产者(制造商)名称、地址

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

生产企业名称、地址

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

产品名称和系列、规格、型号

接触器

TAL30-30, TAL30-30...RT, TAL40-30, TAL40-30...RT Ui: 1000V (690V for TAL RT); Ith: 65A; TAL30: AC-1: 690V/55A; TAL30...RT: AC-1: 690V/50A; TAL30, TAL30...RT: AC-3: Ue/Ie: 220/230/240V/33A, 380/400/415/440V/32A, 500V/28A, 690V/18A; AC-4: Ue/Ie: 220/230/240V/33A, 380/400/415/440V/32A, 500V/23A, 690V/15A; AC-8a: Ue/Ie: 400V/40A; TAL40, TAL40...RT: AC-1: Ue/Ie: 690V/60A; AC-3: Ue/Ie: 220/230/240V/40A, 380/400/415/440V/37A, 500V/33A, 690V/21A; AC-4: Ue/Ie: 220/230/240V/33A, 380/400/415/440V/32A, 500V/23A, 690V/18A; AC-8a: Ue/Ie: 400V/50A; Us: DC17-32V; 极数: 3P; 配用辅助触头: (本体) 1NO/1NC Ith: 16A; AC-15: Ue/Ie: 24-127V/6A, 220-240V/4A, 380-440V/3A, 500-690V/2A; DC-13: Ue/Ie: 24V/6A, 48V/2.8A, 72V/2A, 110-125V/1.1A, 220-250V/0.55A

产品标准和技术要求

GB/T14048.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求, 特发此证。

发证日期: 2017年07月04日 有效期至: 2022年07月04日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2004年12月28日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2004010304138321

NAME AND ADDRESS OF THE APPLICANT

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

NAME AND ADDRESS OF THE MANUFACTURER

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

NAME AND ADDRESS OF THE FACTORY

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

PRODUCT NAME, MODEL AND SPECIFICATION

Contactor

TAL30-30, TAL30-30...RT, TAL40-30, TAL40-30...RT Ui: 1000V (690V for TAL RT) ; Ith: 65A; TA L30: AC-1: 690V/55A; TAL30...RT: AC-1: 690V/50A; TAL30, TAL30...RT: AC-3: Ue/Ie: 220/230/2 40V/33A, 380/400/415/440V/32A, 500V/28A, 690V/18A; AC-4: Ue/Ie: 220/230/240V/33A, 380/400/415/4 40V/32A, 500V/23A, 690V/15A; AC-8a: Ue/Ie: 400V/40A; TAL40, TAL40...RT: AC-1: Ue/Ie: 690V/ 60A; AC-3: Ue/Ie: 220/230/240V/40A, 380/400/415/440V/37A, 500V/33A, 690V/21A; AC-4: Ue/Ie: 2 20/230/240V/33A, 380/400/415/440V/32A, 500V/23A, 690V/18A; AC-8a: Ue/Ie: 400V/50A; Us: DC17- 32V; Poles: 3P; Attached Auxiliary Contacts: 1NO/1NC Ith: 16A; AC-15: Ue/Ie: 24-127V/6A, 220- 240V/4A, 380-440V/3A, 500-690V/2A; DC-13: Ue/Ie: 24V/6A, 48V/2.8A, 72V/2A, 110-125V/1.1A, 220 -250V/0.55A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Jul.04,2017

Valid until: Jul.04,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Dec.28,2004

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE