

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnector

Name and address of the applicant

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the factory

ABB Bulgaria EOOD - Rakovski Branch -
Industrial Zone Rakovski Municipality, 4150 RAKOVSKI
BULGARIA

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

Ie = 16 / 25 / 32 / 40 / 50 / 63 A

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

Series SD200

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007
IEC 60947-1:2007/AMD1:2010
IEC 60947-1:2007/AMD2:2014
IEC 60947-3:2008; 60947-3:2008/AMD1:2012
IEC 60947-3:2008/AMD2:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

249155-TL3-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2018-06-12

Signature:

J. Richter



Ref. Certif. No.

DE1-60505

Additional information (if necessary)

AC-23A: 253 V a.c.; 1-pole, 1+N-pole;

AC-23A: 440 V a.c.; 2-, 3- and 4-pole; 3+N-pole

DC-21A: 60 V d.c.; 1-pole; DC-21A: 125 V d.c.; 2-pole

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2018-06-12

Signature:

J. Richter