



产品认证证书

证书编号: CQC2017010303949759

申请人名称及地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

制造商名称及地址

ABB Stotz-Kontakt GmbH
Hauptstrasse 14-16, D-78132 Hornberg, Germany

生产企业名称及地址

Relpol S. A. (V055275)
ul. 11 Listopada 37, 68-200 Zary, Poland

产品名称和系列、规格、型号

继电器

CR-U(型号解释详见附件); Uimp:2.5kV; Ui:250V; Ith:10A; Ue/Ie:AC-15:AC240V/1.5A; IP40

产品标准和技术要求

GB/T 14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020年09月08日 有效期至: 2022年03月22日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0370626



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2017010303949759

NAME AND ADDRESS OF THE APPLICANT

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB Stotz-Kontakt GmbH
Hauptstrasse 14-16, D-78132 Hornberg, Germany

NAME AND ADDRESS OF THE FACTORY

Relpol S.A. (V055275)
ul.11 Listopada 37, 68-200 Zary, Poland

PRODUCT NAME, MODEL AND SPECIFICATION

Relay
CR-U; Uimp:2.5kV; Ui:250V; Ith:10A; Ue/Ie:AC-15:AC240V/1.5A; IP40

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Sep.08,2020

Valid until: Mar.22,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0370626



产品认证证书

附录

第 1 页 共 1 页

证书编号: CQC2017010303949759

纸号: 370626

型号的解释:

CR-U 024DC 3 L
① ② ③ ④

① basic model 基本型号

② coil voltage 线圈电压

③ number of poles: 2 pole /3 pole 极数: 2 极/3 极

④ accessories 附件: NULL - general relay without any accessories 无 —— 一般继电器, 不带任何附件

L - with LED 带 LED

注: 此附录与证书同时使用时有效。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>