



中国国家强制性产品认证证书

证书编号: 2013010304646569

委托人名称、地址

ABB France

2 rue d'Arsonval 69680 Chassieu France

生产者(制造商)名称、地址

ABB France

2 rue d'Arsonval 69680 Chassieu France

生产企业名称、地址

ABB France

2 rue d'Arsonval 69680 Chassieu France

产品名称和系列、规格、型号

交流接触器

AF*80-30-**-**, AF80-40-**-**, AF80-22-**-**, AF*96-30-**-**; 详见附件

产品标准和技术要求

GB/T 14048.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2020 年 08 月 07 日有效期至: 2023 年 07 月 06 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2013 年 09 月 30 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询
经中国合格评定国家认可委员会认可 CNAS C001-P



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2013010304646569

NAME AND ADDRESS OF THE APPLICANT

ABB France
2 rue d'Arsonval 69680 Chassieu France

NAME AND ADDRESS OF THE MANUFACTURER

ABB France
2 rue d'Arsonval 69680 Chassieu France

NAME AND ADDRESS OF THE FACTORY

ABB France
2 rue d'Arsonval 69680 Chassieu France

PRODUCT NAME, MODEL AND SPECIFICATION

AC Contactor
AF*80-30-**-**, AF80-40-**-**, AF80-22-**-**, AF*96-30-**-**; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO.CNCA-C03-02:2014).

Valid from: Aug.07,2020**Valid until:** Jul.06,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Sep.30,2013

The certificate information is available through CNCA's website: www.cnca.gov.cn
Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2013010304646569

纸 号: 2658790

AF*80-30-**-**, AF80-40-**-**, AF80-22-**-**, AF*96-30-**-**

Ui:1000V;

Uimp:8kV

AF*80-30, AF80-40, AF80-22:

Ith:125A;

Ue/Ie:1000V/50A, 690V/125A (AC-1); 220-440V/80A, 500V/65A, 690V/49A, 1000V/25A (AC-3);

220-500V/65A, 690V/40A (AC-4); 400V/105A (AC-8a) (仅 AF80-30);

AF*96-30:

Ith:130A;

Ue/Ie: 1000V/60A, 690V/130A (AC-1); 220-440V/96A, 500V/80A, 690V/57A,

1000V/30A (AC-3); 220-500V/76A, 690V/45A (AC-4); 400V/120A (AC-8a);

极数: 3P, 4P;

Us: 24-60V 50/60Hz/20-60V d.c., 24-60V 50/60Hz, 48-130V 50/60Hz, d.c.,

100-250V 50/60Hz, d.c., 250-500V 50/60Hz, d.c. ;

IP10;

配用辅助触头: (外置)

CA4-**, CAT4-**, VE4;

Ith: 16A;

AC-15:Ue/Ie: 500-690V/2A, 380-440V/3A, 220-240V/4A, 24-127V/6A;

DC-13:Ue/Ie: 600V/0.1A, 500V/0.13A, 400V/0.15A, 220-250V/0.27A,

110-125V/0.55A, 72V/1A, 48V/4A, 24V/6A;

CAL4-**, CA4-**, CC4-**;

Ith: 16A;

AC-15:Ue/Ie:AC690V/2A, AC500V/2A, AC440V/3A, AC400V/3A, AC240V/4A, AC127V/6A;

DC-13:Ue/Ie:DC600V/0.1A, DC500V/0.13A, DC400V/0.15A,

DC250V/0.27A, DC125V/0.55A,

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2013010304646569

纸 号: 2658790

DC72V/1A, DC48V/4A, DC24V/6A;
1NO, 1NC, 2NO2NC

型号的解释:

AF	S	80	- 30 -	00 -	11
I	II	III	IV	V	VI

I - Main designation : AF

II - Application

Blank - Standard applications

S contactor for safety application

III - Range size

80, 96

III - Main Pole Construction

22 - 2 Normally Opened and 2 Normally Closed main poles.

30 - 3 Normally Opened and 0 Normally Closed main poles.

40 - 4 Normally Opened and 0 Normally Closed main poles.

IV - Auxiliary Pole Construction

00 - No auxiliary pole provided.

11 - One Normally Opened and one Normally Closed auxiliary poles.

22 - Two Normally Opened and two Normally Closed auxiliary poles (AFS only available with this configuration).

V - Coil code

11 : 24-60V 50/60Hz 20-60V DC

41 : 24-60V 50/60Hz

12 : 48-130V 50/60Hz-DC

13 : 100-250V 50/60Hz-DC

14 : 250-500V 50/60Hz-DC

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心