

Certificate



Product Safety

www.tuv.com
ID 060000000

Nr./No.: 968/EZ 555.02/19

Prüfgegenstand Product tested	Safety Rope Switches	Zertifikats- inhaber Certificate holder	ABB AB / Jokab Safety Varlabergsvägen 11 434 39 Kungsbacka Sweden
------------------------------------------	----------------------	------------------------------------------------------------	----------------------------------------------------------------------------

Typbezeichnung Type designation	LineStrong1, LineStrong2 LineStrong2Z LineStrong3D, 3L, 3R LineStrong3DZ, 3LZ, 3RZ
--------------------------------------------	------------------------------------------------------------------------------------------------

Prüfgrundlagen Codes and standards	IEC 60947-5-5:1997+ A1:2005 + A2:2016 EN 60947-5-5:1997+ A1:2005 + A11:2013 + A2:2017 IEC 60947-5-1:2016	EN 60947-5-1:2017 ISO 13850:2015
-----------------------------------------------	----------------------------------------------------------------------------------------------------------------------	-------------------------------------

Bestimmungsgemäße Verwendung Intended application	The products comply with the requirements of the listed standards. The Safety Rope Switches may be used as part of the safety related control system to perform the emergency stop function in accordance with EN ISO 13850.
------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Besondere Bedingungen Specific requirements	The instruction of the associated Installation and Operating Manual shall be considered.
--------------------------------------------------------	------------------------------------------------------------------------------------------

Gültig bis / Valid until 2024-02-15

Der Ausstellung dieses Zertifikates liegt eine Prüfung zugrunde, deren Ergebnisse im Bericht Nr. 968/EZ 555.02/19 vom 08.03.2019 dokumentiert sind.

Dieses Zertifikat ist nur gültig für Erzeugnisse, die mit dem Prüfgegenstand übereinstimmen.

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/EZ 555.02/19 dated 2019-03-08.

This certificate is valid only for products which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH

Bereich Automation

Funktionale Sicherheit

Am Grauen Stein, 51105 Köln

Köln, 2019-03-08

Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. Gebhard Bouwer

www.fs-products.com
www.tuv.com

TÜVRheinland®
Precisely Right.