

DE1-60155

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## **CB TEST CERTIFICATE**

Product

Circuit breaker

Name and address of the applicant

ABB-Stotz-Kontakt GmbH Eppelheimer Straße 82, 69123 Heidelberg **GERMANY** 

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH Eppelheimer Straße 82, 69123 Heidelberg **GERMANY** 

Name and address of the factory

ABB-Stotz-Kontakt GmbH Eppelheimer Straße 82, 69123 Heidelberg **GERMANY** 

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

253 / 440 V a.c.; 110 / 220 / 440 V d.c. In = 0,2 ... 63 A

Characteristic B; C; K; Z

Trademark (if any)

ABB

Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Series S200MTUC

Additional information (if necessary may also be reported on page 2)

□ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007 IEC 60947-1:2007/AMD1:2010 IEC 60947-1:2007/AMD2:2014

IEC 60947-2:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

238067-TL3-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH **VDE** Testing and Certification Institute

Zertifizierung Produkte / Certification Products

Date: 2018-03-22 Signature: Lilul

DE1-60155

Additional information (if necessary)	

## Additional information (if necessary)

Icu = 6 / 10 / 20 / 25 kA Ics = 6 / 7,5 / 10 / 20 kA

Requirements according to national standard VC 8036:2015; Government Notice 1023 of 2015 (Government Gazette No. 39324); SANS 556-1:2012 (power factor 0,5; recovery voltage 252/436 V a.c.) were tested.

**VDE** Prüf- und Zertifizierungsinstitut GmbH **VDE** Testing and Certification Institute Zertifizierung Produkte / Certification Products

Date: 2018-03-22

/ilul
R. Nickel

Signature: