

IEC**IECEE**

®

™

Ref. Certif. No.

CN54728

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Fuse switch disconnector

Name and address of the applicant

ABB Oy
Muottitie 2A FI-65320 VAASA, Finland

Name and address of the manufacturer

ABB Oy
Muottitie 2A FI-65320 VAASA, Finland

Name and address of the factory

ABB Bulgaria EOOD – Rakovski branch
BULGARIA, 4142 Village of Stryama, Region of Plovdiv,
Municipality of Rakovski, Rakovski Industrial Zone, 14 Industrial
Road 1, nr.14-18

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp: 8kV;Ui: 1000V;Ith: 630A, 400A(ZLBM3, ZHBM3, AC800V); AC-21B: Ue/Ie: 690V/630A(ZLBM3, ZHBM3); AC-22B: Ue/Ie: 500V/630A; 800V/400A, 1000V/630A (ZLBM3, ZHBM3); AC-22B: Ue/Ie: 500V/630A, 690V/630A(ZLBM3-BC); AC-23B: Ue/Ie: 400V/630A(ZLBM3, ZHBM3); Iq: ZLBM3,ZHBM3.100 kA, 50kA(AC800V), 120kA(1000Vac); ZLBM3-BC: 100kA(690V), 120kA(500Vac); 50/60Hz,IP30(front),3P

Trademark / Brand (if any)

ABB

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

ZLBM3, ZHBM3, ZLBM3-BC;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020;IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-098872

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Sep.15,2021

Signature:

谢肇旭

Xie ZhaoXu

CB 0064353