



中国国家强制性产品认证证书

证书编号: 2024010302658926

认证委托人名称及地址

ABB S. p. A.

Via Vittor Pisani 16-20124 Milano (MI)-Italy

生产者名称及地址

ABB S. p. A.

V. le dell'Industria 18, 20009 Vittuone (MI), Italy

生产企业名称及地址

NCT S. a. r. l

Lot n° 108, Rue Sfax Zone industrielle Mghira 2 - 2082 Fouchena Ben Arous
(Tunisie)

产品名称和系列、型号、规格

熔断器式隔离开关

E91/20, E92/20, E93/20, E91/32, E91N/32, E92/32, E93/32, E93N/32, E94/32; 详见附件

产品标准和技术要求

GB/T 14048.3-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024) 的要求, 特发此证。

发证日期: 2025年02月17日 有效期至: 2029年07月16日

本证书为变更证书, 证书首次颁发日期: 2024年07月17日
证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号: 2024010302658926

证书附页: 第 1 页 共 2 页

E91/20, E92/20, E93/20, E91/32, E91N/32, E92/32, E93/32, E93N/32, E94/32
Uimp: 6kV;
Ui: 500V;
Ith:20A(E91/20, E92/20, E93/20),32A(E91/32,E91N/32, E92/32, E93/32, E93N/32, E94/32);
Ue:AC400V;
Ie:20A(E91/20, E92/20, E93/20),32A(E91/32,E91N/32, E92/32, E93/32, E93N/32, E94/32);
Iq:20kA;
使用类别: AC-22B;
极数: 1P,1P+N,2P,3P,3P+N,4P;
适用频率: 50/60Hz;
IP20

型号解释:

本页为证书附页, 应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



中国国家强制性产品认证证书

证书编号：2024010302658926

证书附页：第 2 页 共 2 页

E 91/20	1 pole/1 module fuse-switch-disconnector, Ie=20A 1 极 1 模数熔断器式隔离开关, Ie=20A
E 92/20	2 pole/2 module fuse-switch-disconnector, Ie=20A 2 极 2 模数熔断器式隔离开关, Ie=20A
E 93/20	3 pole/3 module fuse-switch-disconnector, Ie=20A 3 极 3 模数熔断器式隔离开关, Ie=20A
E 91/32	1 pole/1 module fuse-switch-disconnector, Ie=32A 1 极 1 模数熔断器式隔离开关, Ie=32A
E 91N/32	1 pole + N pole/2 module fuse-switch-disconnector, neutral pole on the right side, Ie=32A 1 极+中性极 2 模数熔断器式隔离开关, 中性极在右, Ie=32A
E 92/32	2 pole/2 module fuse-switch-disconnector, Ie=32A 2 极 2 模数熔断器式隔离开关, Ie=32A
E 93/32	3 pole/3 module fuse-switch-disconnector, Ie=32A 3 极 3 模数熔断器式隔离开关, Ie=32A
E 93N/32	3 pole + N pole/4 module fuse-switch-disconnector, neutral pole on the right side, Ie=32A 3 极+中性极 4 模数熔断器式隔离开关, 中性极在右, Ie=32A
E 94/32	4 pole/4 module fuse-switch-disconnector, Ie=32A 4 极 4 模数熔断器式隔离开关, Ie=32A

本页为证书附页，应与证书主页同时使用。



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010302658926

NAME AND ADDRESS OF THE APPLICANT

ABB S.p.A.
Via Vittor Pisani 16-20124 Milano (MI)-Italy

NAME AND ADDRESS OF THE MANUFACTURER

ABB S.p.A.
V.le dell'Industria 18, 20009 Vittuone (MI), Italy

NAME AND LOCATION OF THE FACTORY

NCT S.a.r.l
Lot n°108, Rue Sfax Zone industrielle Mghira 2 – 2082 Fouchena Ben Arous (Tunisie)

PRODUCT NAME,MODEL AND SPECIFICATION

FUSE SWITCH DISCONNECTORS
E91/20, E92/20, E93/20, E91/32, E91N/32, E92/32, E93/32, E93N/32, E94/32;See the appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.3-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Feb.17,2025 **Valid until:** Jul.16,2029

Date of original issued: Jul.17,2024

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010302658926

Appendix: Page 1 of 1

E91/20, E92/20, E93/20, E91/32, E91N/32, E92/32, E93/32, E93N/32, E94/32
Uimp: 6kV;
Ui: 500V;
Ith:20A(E91/20, E92/20, E93/20),32A(E91/32,E91N/32, E92/32, E93/32, E93N/32,
E94/32);
Ue:AC400V;
Ie:20A(E91/20, E92/20, E93/20),32A(E91/32,E91N/32, E92/32, E93/32, E93N/32,
E94/32);
Iq:20kA;
Utilization Category: AC-22B;
Poles: 1P,1P+N,2P,3P,3P+N,4P;
50/60Hz;
IP20

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.