


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

| | |
|---|---|
| Product | DALI Gateway |
| Name and address of the applicant | ABB STOTZ-KONTAKT GmbH Eppelheimerstraße 82, 69123 Heidelberg Germany |
| Name and address of the manufacturer | ABB STOTZ-KONTAKT GmbH Eppelheimerstraße 82, 69123 Heidelberg Germany |
| Name and address of the factory | <input type="checkbox"/> Additional information on page 2 ABB STOTZ-KONTAKT GmbH Hauptstraße 14-16, 78132 Hornberg Germany |
| Note: When more than one factory, please report on page 2 | |
| Ratings and principal characteristics | input: 100-240 Vac; 50/60 Hz 110-240 Vdc max 2 W KNX i-bus and & DALI bus |
| Trademark (if any) |  BUSCH-JAEGER and ABB |
| Customer's Testing Facility (CTF) Stage used | CTF Stage 3 |
| Model / Type Ref. | for ABB DG/S1.64.1.1; DG/S2.64.1.1; DG/S1.64.5.1; DG/S2.64.5.1 DG-M-1.16.1 for BUSCH-JAEGER DG/S1.64.1.11; DG/S2.64.1.11; DG/S1.64.5.11; DG/S2.64.5.11 DG-M-1.16.11 |
| Additional information (if necessary may also be reported on page 2) | <input type="checkbox"/> Additional information on page 2 |
| A sample of the product was tested and found to be in conformity with | IEC 60669-1:1998, IEC 60669-1:1998/AMD1:1999, IEC 60669-1:1998/AMD2:2006, IEC 60669-2-1:2002, IEC 60669-2-1:2002/AMD1:2008, IEC 60669-2-1:2002/AMD2:2015, IEC 60669-2-5:2013 National differences: EU Group Differences 2240112.50 |
| As shown in the Test Report Ref. No. which forms part of this Certificate | |

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands