



LCIE

ATTESTATION OF CONFORMITY

N°: 147847-701659 Ax

Version : 01

Subject Dielectric test on auxiliary contact linked with power contact

Issued to **ABB France**
3 rue Jean PERRIN
CS 90009
69687 CHASSIEU CEDEX

Apparatus under test

- ↪ Product Electromechanical control circuit devices (see page 3)
- ↪ Applied specification Annex F - IEC 60947-4-1 Ed3.1 (2012-07)
- ↪ Models AF range


Tests results

A sampling of the product has been tested and found to be in conformity with the requirements of the tests performed. Tests conditions and results are given in the LCIE test report n° 147847-701659A, tests reports and attestations n°117421-634851 and 117421-634851A (2013).

Composition of the document 3 pages
Document issued on 21st June 2017

Written by :
F. COPIN
Tests operator

Approved by :
P. RODDE
Technical manager



This document shall not be reproduced, except in full, without the written approval of the LCIE. This document contains results related only to the item tested. It does not imply the conformity of the item tested. This document doesn't anticipate any certification decision.



PUBLICATION HISTORY

Version	Date	Author	Modification
01	21/06/2017	F. COPIN	Creation of the document



PRODUCT

Range	Range size	Coil type	Main pole	Auxiliary contacts fitted	Terminal	Additional auxiliary contact blocks
AF	09 or 12 or 16	(Z)(B)	-30	01 or 10 or 22	(RT)(S)	With CA4-01 or CAT4-11 or CA4-04 or CA4-13 or CA4-22 or CA4-31 and/or CAL4-11
AF	26 or 30 or 38	(Z)(B)	-30	00 or 11 or 22	(RT)(S)	With CA4-01 or CAT4-11 or CA4-04 or CA4-13 or CA4-22 or CA4-31 and/or CAL4-11
AF	40 or 52 or 65 or 80 or 96	(B)	-30	00 or 11 or 22		With CA4-01 or CAT4-11 (only for AF40 to AF65) or CA4-04 or CA4-13 or CA4-22 or CA4-31 and/or CAL4-11
AF	09 or 16 or 26 or 38	(Z)(B)	-40 or -22	00	(RT)(S)	With CA4-01 or CAT4-11 or CA4-04 or CA4-13 or CA4-22 or CA4-31 and/or CAL4-11
AF	40 or 52 or 65 or 80 or 96	(B)	-40 or -22	00		With CA4-01 or CAT4-11 (only for AF40 to AF65) or CA4-04 or CA4-40 or CA4-13 or CA4-22 or CA4-31 and/or CAL4-11