

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit breaker

Name and address of the applicant

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the factory

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

☐ Additional Information on page 2
133 / 230 V a.c.; 230 / 440 V a.c.;
In = 0,5 ... 63 A; Characteristic B; C; D; K; Z
Icu = 10 / 20 kA; Ics = 7,5 / 15 kA

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Series S200

Additional information (if necessary may also be reported on page 2)

☒ Additional Information on page 2

A sample of the product was tested and found to be in conformity with


IEC 60947-1:2007
IEC 60947-1:2007/AMD1:2010
IEC 60947-1:2007/AMD2:2014
IEC 60947-2:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

244192-TL3-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products



Date: 2018-01-22

Signature: J. Richter



Ref. Certif. No.

DE1-59872

Additional information (if necessary)

Requirements according to national standard VC 8036:2015; Government Notice 1023 of 2015 (Government Gazette No. 39324); SANS 556-1:2012 (power factor 0,5; recovery voltage 252/436 V a.c.) were tested.

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2018-01-22

Signature:

J. Richter