



中国国家强制性产品认证证书

证书编号：2013010304646607

委托人名称、地址

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

生产者（制造商）名称、地址

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

生产企业名称、地址

ABB 新会低压开关有限公司

广东省江门市新会区今古洲工业开发区

产品名称和系列、规格、型号

接触器

AX50-30-□□-□□、AX65□-30-□□-□□、AX80□-30-□□-□□；参数及型号解释见附件

产品标准和技术要求

GB/T14048. 4-2010

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，特发此证。

发证日期：2018 年 11 月 13 日 有效期至：2023 年 05 月 17 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2013 年 09 月 30 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2013010304646607

NAME AND ADDRESS OF THE APPLICANT

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

NAME AND ADDRESS OF THE MANUFACTURER

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

NAME AND ADDRESS OF THE FACTORY

ABB Xinhui Low Voltage Switchgear Co., Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province,
P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Contactors
AX50-30-□□-□□,AX65-30-□□-□□,AX80-30-□□-□□; See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Nov.13,2018

Valid until: May.17,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Sep.30,2013

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 3 页

证书编号: 2013010304646607

纸 号: 2096792

AX50-30-□□-□□, AX65□-30-□□-□□, AX80□-30-□□-□□;

U_{imp} : 6kV;

U_i : 690V;

I_{th} : AX50: 100A, AX65□, AX80□: 125A;

U_s :

频率 Hz	U_s (V)										
	线圈代号										
	81	83	26	84	36	75	80	44	88	85	86
50	24	48	105	110	190	200	220-230	220-230	230-240	380-400	400-415
60	24	48	110-127	110-120	220	200-220	230-240	/	240-260	400-415	415-440

使用类别, U_c , I_c :

使用类别	U_c (V)	I_c (A)		
		AX50	AX65□	AX80□
AC-3	220-230-240	53	65	80
AC-3	380-400	50	65	80
AC-3	415	50	65	80
AC-3	440	45	65	70
AC-3	500	45	55	65
AC-3	690	35	43	46
AC-8a	400	63	85	95
AC-1	690	100	115	125

3P;

IP10;

配用的辅助触头:

CAL5-11, CAL5X-11; I_{th} : 16A;

1NO1NC

使用类别, U_c , I_c :

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 3 页

证书编号：2013010304646607

纸 号：2096792

使用类别	$U_e(V)$	$I_e(A)$
AC-15	AC24-127	6
AC-15	AC220-240	4
AC-15	AC380-440	3
AC-15	AC500-690	2
DC-13	DC24	6
DC-13	DC48	2.8
DC-13	DC72	1
DC-13	DC110	0.55
DC-13	DC125	0.55
DC-13	DC225	0.3
DC-13	DC250	0.3

注：此附录与证书同时使用时有效。



主 任：



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 3 页 共 3 页

证书编号：2013010304646607

纸 号：2096792

型号的解释：

AX □□ □ - 3 0 - □□ - □□

控制线圈型号代码：见表一

附件种类数量：00-没有附加附件；11-附加一只附件 CAL5-11 或 CAL5X-11

常闭主触点对数 0：0 对常闭主触点

常开主触点对数 3：3 对常开主触点

空白：用于常规市场需求；J：根据销售要求指定细分市场仅适用于 AX65、AX80，AX65J、AX80J 仅适用于线圈代号 44

AC380V 工作电压，AC-3 下额定工作电流(A)

50:50A；65:65A；80:80A

系列名称：AX 系列接触器

其中表一见报告 (02301-03-180482) 第 9 页。

注：此附录与证书同时使用时有效。



主 任：



中国质量认证中心