



NOTES:

1. WARNING: This drawing does not illustrate the installation methods required for hazardous locations. Prior to any installation in a Classified Hazardous Location, verify installation methods by the Control Drawing referenced on the product's name tag and national and local codes.
2. This drawing is for a 12V system.



Note:  
AIs connected to J23 are configurable for either Volts or milliAmps by switching the set of jumpers lined above it.

J21 J22  
1 3 1 3

In this configuration, jumper J21 & J22 pin numbers 1 to 2 for 4-20mA input.

REF: N/A

	TOTALFLOW	ACTION	DOC TYPE	TITLE	DWG NO.	REV	SHEET
	Products	L33600	UD	XRC <sup>G4</sup> (2103329 BD) AI TO ABB 266 Pressure Transmitter using a 12V System	2104925	AA	1 OF 1