
TECHNICAL DATA SHEET - INTERACTIVE PDF

Bell Ends, PVC

Carlton[®]



PVC bell ends for schedule 40 and 80 rigid pvc conduits

Certifications / Standards:



3-Part Specification:
End User Tools

Features:

- Rounded pulling surface for smooth cable pulling
- Superior molded finish

Applications:

- Used in concrete vault walls to provide smoother, safer cable entrance to the PVC conduits. Protects cables while pulling.

Conforms to:

- NEMA TC-9

Material / Finishes:

- Rigid PVC / Gray

Bell End, PVC

Product selection - inches (mm)											
Part no.	Size	A	B	D	O.D.	X	Y	C	N	L	R
E997F	1"	1.325	1.312	1.225	1.525	1.756	1.788	1.515	0.375	1.890	0.312
E997F-CAR		(33.7)	(33.3)	(31.1)	(38.7)	(44.6)	(45.4)	(38.5)	(9.5)	(48.0)	(7.9)
E997G	1 ¼"	1.673	1.662	1.540	1.882	2.01	2.145	1.515	0.375	1.890	0.312
E997G-CAR		(42.5)	(42.2)	(39.1)	(47.8)	(51.1)	(54.5)	(38.5)	(9.5)	(48.0)	(7.9)
E997H	1 ½"	1.910	1.900	1.765	2.125	2.255	2.385	1.519	0.375	1.894	0.312
E997H-CAR		(48.5)	(48.3)	(44.8)	(54.0)	(57.3)	(60.6)	(38.6)	(9.5)	(48.1)	(7.9)
E997J	2"	2.393	2.369	2.193	2.663	2.990	2.958	1.135	0.357	1.492	0.200
E997J-CAR		(60.8)	(60.2)	(55.7)	(67.6)	(75.9)	(75.1)	(28.8)	(9.1)	(37.9)	(5.1)
E997K	2 ½"	2.890	2.868	2.460	3.062	3.480	3.488	1.48	0.520	2.00	0.250
E997K-CAR		(73.4)	(72.8)	(62.5)	(77.8)	(88.4)	(88.6)	(37.6)	(13.2)	(50.8)	(6.4)
E997L	3"	3.515	3.492	3.069	3.688	4.09	4.09	1.610	0.390	2.00	0.250
E997L-CAR		(89.3)	(88.7)	(77.9)	(93.7)	(103.9)	(103.9)	(40.9)	(9.9)	(50.8)	(6.4)
E997M	3 ½"	4.018	3.993	3.540	4.226	4.598	4.598	1.695	0.440	2.135	0.250
		(102.1)	(101.4)	(85.2)	(107.3)	(116.8)	(116.8)	(43.1)	(11.2)	(54.2)	(6.4)
E997N	4"	4.515	4.482	4.020	4.995	5.310	5.230	1.780	0.479	2.259	0.380
		(114.7)	(113.8)	(102.1)	(126.9)	(134.9)	(132.8)	(45.2)	(12.2)	(57.4)	(9.6)
E997P *	5"	5.590	5.550	4.990	5.880	6.160	6.160	1.950	0.440	2.380	0.380
		(142.0)	(141.0)	(126.7)	(149.4)	(156.5)	(156.5)	(49.5)	(11.2)	(60.5)	(9.7)
E997R *	6"	6.660	6.610	5.990	6.960	7.160	7.160	2.140	0.440	2.580	0.380
		(169.2)	(167.9)	(152.1)	(176.8)	(181.9)	(181.9)	(54.4)	(11.2)	(65.5)	(9.7)

Note: Product must be installed in accordance with applicable national and local electrical codes.

* Not UL Listed or CSA Certified

