Common mode filter kit for ACS880-01 drives (frame R9, option +E208)

Installation instructions

1,5 N·m

Make sure that the grounding conductor is longer than the phase conductors.

T1/U, T2/V, T3/W		⏚
T (Wire screw)		T
M…	N·m	N·m
M10	30	9.8

> 59 [2.32 in]

≤ 96 [3.78 in]

≥ 132 [5.20 in]

≤ 170 [6.70 in]

≤ 26 [1.02 in]

abb.com/drives

ABB