



Test Report				Date of issue: 4.6.2014					
				Serial No.: 3GF11094410					
				Type: M3KP 160MLC 8 IMB3/IM1001					
				Product Code: 3GKP164430-ADH					
				Protection type: Ex de IIB T4 Gb					
				Cert. No.: LCIE 11 ATEX 3087X / IECEx LCI 09.0008X					
Rating:									
	V	Hz	kW	r/min	A	cos φ	Duty		
3~Motor	690	Y 50	7,5	718	10,5	0,70	S1		
Insul.cl.F	400	D 50	7,5	718	18	0,70	S1		
IP55	415	D 50	7,5	721	17,6	0,69	S1		
Resistance		Ambient: 23,0 °C		Insulation resistance at 48,0 °C		Overload			
Line				2400 MΩ	1000 V		Torque 160 % 15s		
U <sub>1</sub> - V <sub>1</sub>			0,99700 Ω						
U <sub>1</sub> - W <sub>1</sub>			0,99710 Ω						
V <sub>1</sub> - W <sub>1</sub>			0,99730 Ω						
				High-voltage test winding 2900 V		1 s			
Test	Torque [Nm]	Line U[V]	f[Hz]	Input I[A]	P1 [kW]	Output P2 [kW]	n[r/min]	cos φ	η [%]
No load test		400,0 D	50	11,2	0,53		748	0,07	
Locked rotor test		125,6 D	50	17,9	1,81		0	0,46	
Thermal test (100% load)	99,8	400,1 D	50	19,3	9,41	7,50	700	0,71	79,7
Partial load points:									
~75% load	74,8	400,0 D	50	15,8	6,87	5,62	716	0,63	81,9
~50% load	49,7	400,1 D	50	13,0	4,58	3,75	729	0,51	81,9
~25% load	24,9	400,0 D	50	11,3	2,47	1,87	740	0,32	75,8
Temperature rise at rated load.		[°C]		[K]	Method		Measurement method		
Stator winding :				88,4	1		1 Resistance		
Frame :				52,6	2		2 Thermometer		
Bearing D-end :				50,0	2		3 Thermocouples		
Rotor :				115,5	3				
Ambient Temperature :		25,0			2				
Manufactured and tested in accordance with rules of IEC 60034-1 and IEC 60034-2-1. PLL determined from residual loss.									
On behalf of customer									
On behalf of manufacturer		Date of test		3.4.2012					
Tested by ABB Oy, Motors and Generators, Vaasa, Finland						Telephone +358 10 2211 Telefax +358 10 22 47372			

Computer print-out valid without signature.

**ABB, Motors and Generators**  
www.abb.com/motors&generators