



Test Report				Date of issue: 15.8.2013						
Customer: ABB OY				Serial No.: 3GF11094427						
Order No.: 599608-1				Type: M3GP 160MLA 2 IMB3/IM1001						
Product Code: 3GGP161410-ADD				Protection type: Ex nA II C T3 Gc						
Cert. No.: LCIE 13 ATEX 1034 X				IECEX LCIE 13.0047X						
Rating:										
		V	Hz	kW	r/min	A	cos φ	Duty		
3~Motor		690	Y 50	11	2931	11,4	0,89	S1		
Insul.cl.F		400	D 50	11	2931	19,7	0,89	S1		
IP55		415	D 50	11	2937	19,7	0,86	S1		
Eff class IE2		50Hz : IE2 - 90.1(100%) - 90.5(75%) - 89.6(50%)								
Resistance				Insulation resistance at 41,5 °C				Overload		
Line Ambient: 20,0 °C				31000 MΩ 1000 V				Torque 160 %		15s
U <sub>1</sub> - V <sub>1</sub>		0,50820 Ω								
U <sub>1</sub> - W <sub>1</sub>		0,50850 Ω								
V <sub>1</sub> - W <sub>1</sub>		0,50880 Ω								
				High-voltage test winding 2900 V				1 s		
Test	Torque [Nm]	Line U[V]	f[Hz]	Input I[A]	P1 [kW]	Output P2 [kW]	n[r/min]	cos φ	η [%]	
No load test		400,0 D	50	6,40	0,53		2998	0,12		
Locked rotor test		78,1 D	50	19,7	1,09		0	0,41		
Thermal test ( 100% load )	35,8	400,0 D	50	20,3	12,3	11,0	2926	0,88	89,3	
Partial load points:										
~75% load	26,8	400,1 D	50	15,7	9,21	8,25	2947	0,85	89,5	
~50% load	17,8	400,0 D	50	11,6	6,23	5,50	2964	0,78	88,3	
~25% load	9,1	400,1 D	50	8,18	3,34	2,75	2981	0,59	82,4	
Temperature rise at rated load.				°C	[K]	Method		Measurement method		
Stator winding :				53,1	1	1 Resistance		1 Resistance		
Frame :				20,2	2	2 Thermometer		2 Thermometer		
Bearing D-end :				36,0	2	3 Thermocouples		3 Thermocouples		
Rotor:					3					
Ambient Temperature :				25,0	2					
Manufactured and tested in accordance with rules of IEC 60034-1 and IEC 60034-2-1. PLL determined from residual loss.										
On behalf of customer										
On behalf of manufacturer				Date of test 8.12.2011						
Tested by ABB Oy, Motors and Generators, Vaasa, Finland						Telephone +358 10 2211 Telefax +358 10 22 47372				

Computer print-out valid without signature.

