

PCM600 version 2.11



2022-06-17 EXTERNAL RELEASE NOTE

Release of Hotfix of Protection and Control IED Manager PCM600 version 2.11.

Release authorized by:

Raghuvendra Singh, Global Product Manager
Hitachi Energy, Grid Automation and Communication

A hotfix package for Protection and Control IED Manager PCM600 version 2.11 has been released. We highly recommend the installation of this hotfix 20220617 when using PCM600 version 2.11.

Please refer next section for more details about improvements and corrections done in the hotfix.

1. Improvements and corrections



Improvements and corrections:

- Fix for cases where communication configuration with SMV did not work as expected for certain IED families.
- Inconsistencies with GOOSE communication after PCM600 project migration corrected.
- Improved robustness of Communication connection.
- Improved robustness of Update Manager with installed language add-ons.

STATUS	SECURITY LEVEL	DOCUMENT ID	REV.	LANG.	PAGE
Approved	Public	1MRG503598	A	en	2/3

- Improved handling of high DPI settings.
- Improved handling of measurement labels in Graphical Display Editor.
- Improved robustness in interoperability with third party IEDs.
- Fix for error scenarios where configuring some IEDs failed when example configuration (*.pcmi) option is selected in IED configuration wizard.

The Hotfix 20220617 for PCM600 version 2.11 is available via the PCM600 Update Manager and Software Library. It contains the following file:

- **PCM600 2.11 Hotfix 20220617.exe**

This hotfix includes also the previously released hotfix for PCM600 version 2.11:

- PCM600 2.11 Hotfix 20220318.exe

We recommend the installation of this Hotfix 20220617 when using PCM600 version 2.11.

For more information, please contact your local Hitachi Energy representative.

Hitachi Energy constantly examines both operational and new software to identify possible faults or product improvements, issuing hotfixes where appropriate. We apologize for any inconvenience the identified faults have caused.

2. Known limitations

- 1) Avoid using F3 key when working with data grid in PCM600 version 2.11 and hotfixes.

Hitachi Energy

Grid Automation Products
SE-721 59 Västerås, Sweden
Tel. +46 10 738 00 00

Copyright 2022 Hitachi Energy. All rights reserved

We reserve the right to make technical changes or modify the contents of this document without prior notice. With regard to purchase orders, the agreed particulars shall prevail. Hitachi Energy does not accept any responsibility whatsoever for potential errors or possible lack of information in this document.

We reserve all rights in this document and in the subject matter and illustrations contained therein. Any reproduction, disclosure to third parties or utilization of its contents – in whole or in parts – is forbidden without prior written consent of Hitachi Energy.

STATUS	SECURITY LEVEL	DOCUMENT ID	REV.	LANG.	PAGE
Approved	Public	1MRG503598	A	en	3/3