



产品认证证书

证书编号: CQC2017010303941444

申请人名称及地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

制造商名称及地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

生产企业名称及地址

EOLANE Maroc (V054938)
Lot 11 - Zone Industrielle Route de Marrakech Berrechid Morocco

产品名称和系列、规格、型号

继电器

RB...: Ui:250V;Uimp:4kV;除 RB...122A 以外: AC-12: Ue/Ie: AC230V/6A; AC-15: Ue/Ie: AC230V/1.5A; DC-12: Ue/Ie: DC24V/6A; DC-13: Ue/Ie: DC24V/1A; DC-13: Ue/Ie: DC110V/0.2A; DC-13: Ue/Ie: DC220V/0.1A; RB...122A: AC-12: Ue/Ie: AC230V/8A; AC-15: Ue/Ie: AC230V/1.5A; DC-12: Ue/Ie: DC24V/8A; DC-13: Ue/Ie: DC24V/1A; DC-13: Ue/Ie: DC110V/0.2A; DC-13: Ue/Ie: DC220V/0.1A; Ith: 6A(除 RB...122A 以外), 8A(RB...122A);外壳防护等级: IP20

产品标准和技术要求

GB/T14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 09 月 02 日 有效期至: 2022 年 02 月 20 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0334200



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2017010303941444

NAME AND ADDRESS OF THE APPLICANT

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE FACTORY

EOLANE Maroc (V054938)
Lot 11 - Zone Industrielle Route de Marrakech Berrechid Morocco

PRODUCT NAME, MODEL AND SPECIFICATION

Relay

RB...: Ui:250V;Uimp:4kV;Except RB...122A : AC-12: Ue/le: AC230V/6A; AC-15: Ue/le: AC230V/1.5A; DC-12: Ue/le: DC24V/6A; DC-13: Ue/le: DC24V/1A; DC-13: Ue/le: DC110V/0.2A; DC-13: Ue/le: DC220V/0.1A; RB...122A: AC-12: Ue/le: AC230V/8A; AC-15: Ue/le: AC230V/1.5A; DC-12: Ue/le: DC24V/8A; DC-13: Ue/le: DC24V/1A; DC-13: Ue/le: DC110V/0.2A; DC-13: Ue/le: DC220V/0.1A; lth: 6A(Except RB...122A), 8A(RB...122A);IP20

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Sep.02,2020

Valid until: Feb.20,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0334200



产品认证证书

附录

第 1 页 共 1 页

证书编号: CQC2017010303941444

纸号: 334200

型号解释:

Example: (举例)	RB	R	121	R	-	230VUC
	I	II	III	IV		V

I	Product series (产品系列)	RB series (RB 系列)	
II	Terminal Type (端子类型)	Empty (空):	screw terminal (螺钉端子)
		R:	spring terminal (弹簧端子)
III	Contact types (触点类型)	101:	1 n/c contact (1 个常闭触点)
		111:	1 n/o contact (1 个常开触点)
		121:	1 c/o contact (1 对转换触点)
		122:	2 c/o contact (2 对转换触点)
IV	Additional features (额外特性)	empty	w/o additional features (无额外特性)
		R	RC-Protection (RC-回路保护)
		P	Polarisiert: Free Wheeling Diode (Freilaufdiode) (极性保护: 续流二极管)
		G	Gold Plated Contacts (镀金触点)
V	Coil voltages (线圈电压)	DC-Version (直流型号)	AC/DC-Version (交直流通用型号)
		5 V DC	24 V UC
		12 V DC	48-60 V UC
		24 V DC	115 V UC
			230 V UC
	60-230 V UC		

注: 此附录与证书同时使用时有效。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>