

ACS800 PARAMETER LOCK FUNCTION

Description:

The parameter 16.02 “Parameter Lock”, does this lock just the control panel or does it lockout fieldbus and Drive Window software from making parameter changes in the ACS800 drive?

Index	Name/Selection	Description
16.02	PARAMETER LOCK	Selects the state of the parameter lock. The lock prevents parameter changing.
	OPEN	The lock is open. Parameter values can be changed.
	LOCKED	Locked. Parameter values cannot be changed from the control panel. The lock can be opened by entering the valid code to parameter 16.03 .

Answer:

The parameter 16.02 “Parameter Lock” only locks the control panel from making parameter changes in the ACS800. The parameters can be changed from fieldbus and Drive Window software even when the Parameter Lock is active.

Documents or other reference material:

ACS800 Standard Control Program 7.x, Firmware Manual
3AFE64527592

Corrective Actions:

None

Author: Jeff Fell, Louis Chatfield – Application Eng.		Date: 11, 2013
External http://www.abb.us/drives .	Industry – Industrial	Document #: LVD-EOTN50U-EN
Revision: A		
Product Categories: ACS800		