



# 产品认证证书

证书编号: CQC2007010305248106

申请人名称及地址

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

制造商名称及地址

ABB 新会低压开关有限公司

广东省江门市新会区今古洲工业开发区

生产企业名称及地址

ABB 新会低压开关有限公司 (V005372)

广东省江门市新会区今古洲工业开发区

产品名称和系列、规格、型号

接触器式继电器

NS、NSL: Ui:690V; Uimp:6kV; Ith:10A; AC-15:Ue/Ie:24-127V/6A, 220-240V/4A, 380-440V/3A, 500-690V/2A,  
DC-13:Ue/Ie:24V/6A, 48V/2.8A, 72V/1A, 110V/0.55A, 220-250V/0.3A;  
Us:AC:24V,42V,48V,110V,115V,220V,230V,240V,400V, 415V(50/60Hz),120V,277V(60Hz),380V(50Hz),  
DC:12V,24V,48V,60V,110V,125V,220V,240V; IP20: 型号解释见附件

产品标准和技术要求

GB/T14048.5-2017

认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020年08月14日 有效期至: 2024年08月09日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: 陆楠



## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0346455



# PRODUCT CERTIFICATE

**CERTIFICATE NO.:** CQC2007010305248106

**NAME AND ADDRESS OF THE APPLICANT**

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

**NAME AND ADDRESS OF THE MANUFACTURER**

ABB Xinhui Low Voltage Switchgear Co.,Ltd.

Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China

**NAME AND ADDRESS OF THE FACTORY**

ABB Xinhui Low Voltage Switchgear Co.,Ltd. (V005372)

Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China

**PRODUCT NAME, MODEL AND SPECIFICATION**

Contactor Relays

NS、NSL: Ui:690V; Uimp.6kV; Ith:10A; AC-15:Ue/Ie:24-127V/6A, 220-240V/4A, 380-440V/3A, 500-690V/2A, DC-13:Ue/Ie:24V/6A, 48V/2.8A, 72V/1A, 110V/0.55A, 220-250V/0.3A; Us:AC:24V,42V,48V,110V,115V,220V,230V,240V,400V, 415V(50/60Hz),120V,277V(60Hz),380V(50Hz), DC:12V,24V,48V,60V,110V,125V,220V,240V; IP20; See the Appendix

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T14048.5-2017

**TYPE OF CERTIFICATION SCHEMES**

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Aug.14,2020

Valid until: Aug.09,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: \_\_\_\_\_

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0346455



# 产品认证证书

附录


第 1 页 共 1 页

证书编号: CQC2007010305248106

纸号: 346455

型号解释:

NSL 8 Q E S — 8I



线圈型号

接线方式:有 S 为弹簧接线, 无 S 为线夹螺钉接线

EN50011 标准定义的接触器继电器的特征符号

常闭辅助触点对数: 0, 1, 2, 3, 4

常开辅助触点对数: 8, 7, 6, 5, 4, 3, 2

系列名称: 低压接触器式继电器

NS 表示控制回路为交流

NSL 表示控制回路为直流

注: 此附录与证书同时使用时有效。

主任: 陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>