



Product Service

Choose certainty.  
Add value.

# ATTESTATION OF CONFORMITY

## Konformitätsbescheinigung

To CEI 0-21:2019 specifications  
für CEI 0-21:2019 Anforderungen

Attestation number: AoC-44254-61719-01  
/ Bescheinigungsnummer

Issued to: **ABB Stotz-Kontakt GmbH**  
/ Ausgestellt für Eppelheimer Str. 82, 69123 Heidelberg Germany

Manufacturer: **ABB Stotz-Kontakt GmbH**  
/ Hersteller Eppelheimer Str. 82, 69123 Heidelberg Germany

Product type:  
/ Produkttyp

<i>Interface Protective Device / NA-Schutz</i>	<i>Static Conversion Device / Wechselrichter</i>
X	---

Model reference:  
/ Modell

<i>Model / Modell</i>	<i>Ratings / Nennwerte</i>
CM-UFD.M22M	Power supply: 24-240Vac / 24-240Vdc Monitoring line: 230/400 50Hz Firmware: rev. 1.0.3

Requirements: CEI 0-21:2019 – Reference technical rules for the connection of active and passive users to the  
/ Prüfgrundlage LV electrical utilities.

Testing Laboratory: TÜV SÜD Product Service GmbH,  
/ Prüflabor Äußere Frühlingstraße 45 D-94315 Straubing

Test Report No: TR-44254-61719-01 (PD)  
/ Prüfberichts Nr.

The undersigned declares that the above described product meets the above mentioned technical specification. This attestation of conformity is issued based on the test results as laid down in the referred test report/s. The investigation does not include an assessment of the manufacturer's production.

*/ Der Unterzeichnende erklärt dass das oben beschriebene Produkt die oben genannte technische Spezifikation erfüllt. Diese Konformitätsbescheinigung wird auf Grundlage der in dem/den vorliegenden Prüfbericht(en) festgestellten Prüfergebnisse erteilt. Die Untersuchung beinhaltet keine Beurteilung der Produktion des Herstellers.*

Date of issue: 19/06/2019  
/ Freigabe Date

Technical approval:  
Gian Maria Fontolan

Valid up to: 19/06/2022  
/ Gultig bis

Duplication of this Attestation of compliance is not allowed, if not in integral, without written permission of TÜV SÜD.